



ELEKTROTECHNICKÝ

ZKUŠEBNÍ ÚSTAV



CZ-1531-A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product Produit

Name and address of the applicant Nom et adresse du demandeur

Name and address of the manufacturer Nom et adresse du fabricant

Name and address of the factory Nome et adresse de l'usine

Ratings and principal characterístics Valeurs nominales et caractéristiques principales

Trademark (if any)
Marque de fabrique (si elle existe)

Model / Type Ref. Ref. De type

Additional information (if necessary) Information complémentaire (si nécessaire)

A sample of the product was tested and found to be in conformity with Un échantillon de ce produit a été essayé et a été considéré conforme à la

As shown in the Test Report Ref. No. which forms part of this Certificate

Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

Circuit-breakers for overcurrent protection for household and similar installation

BONEGA, VELKOOBCHOD, spol. s r. o. Sudoměřice č.302, 696 66 Sudoměřice, Czech Republic

BONEGA, VELKOOBCHOD, spol. s r. o. Sudoměřice č.302, 696 66 Sudoměřice, Czech Republic

BONEGA, VELKOOBCHOD, spol. s r. o. Sudoměřice č.302, 696 66 Sudoměřice, Czech Republic

AC 230/400 V(1p), 400 V(3p), 50/60 Hz, number of poles: 1, 1+N, 2, 3, 3+N, 4, char.: B, C, D, In:1, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63 A, 10 kA

PEP-10J

PUBLICATION

EDITION

IEC 60898-1

1995

500097-01/01 of: 14.02.2005

This CB Test Certificate is issued by the National Certification Body Ce Certificat d'essai OC est établi par l'Organisme National de Certification

Elektrotechnický zkušební ústav Pod lisem 129, 171 02 Praha 8 – Troja Czech Republic

Date: 2.3.2005

Signature: Pavel Kudrna

Certification and Inspection Manager



TEST REPORT IEC 60 898

Circuit-Breakers for overcurrent protection for household and similar installation

Report reference No		
Signature) Approved by (printed name and signature) Date of issue	Report reference No	500097-01/ 01/1
Approved by (printed name and signature) Date of issue		Jaroslav Klípa
Signature) Date of issue 14.02.2005 This report is based on a blank test report that was prepared by SGS Fimko Ltd using information obtained from the TRF originator (see below). Testing Laboratory Name Elektrotechnický zkušební ústav Address Pod Lisem 129 Testing location 171.02 Praha 71-Troja, Czech Republic Applicant's Name BONEGA Velkoobchod s.r.o. Address 696.66 Sudoměřice nad Moravou 302, Czech Republic Test specification Standard IEC 60898 (2 nd ed):1995 Test procedure CB Procedure deviation N/A Non-standard test method N/A Test Report Form Test Report Form No. 60898_A/00-12 TRF originator OVE Master TRF dated 00-07 Copyright reserved to the bodies participating in the IECEE Schemes (CB and CB-FCS) and/or the bodies participating in the C.I.G (CCA-ENEC). Test item description Circuit breakers for overcurrent protection for household and similar installation Trademark BONEGA Series PEP-10J Model and/or type reference PEP-10J D 63 (1p)		Jan Hlavatý
This report is based on a blank test report that was prepared by SGS Fimko Ltd using information obtained from the TRF originator (see below). Testing Laboratory Name		
from the TRF originator (see below). Testing Laboratory Name	Date of issue	14.02.2005
Address Pod Lisem 129 Testing location 171 02 Praha 71-Troja, Czech Republic Applicant's Name BONEGA Velkoobchod s.r.o. Address 696 66 Sudoměřice nad Moravou 302, Czech Republic Test specification Standard IEC 60898 (2 nd ed):1995 Test procedure CB Procedure deviation N/A Non-standard test method N/A Test Report Form Test Report Form No. 60898_A/00-12 TRF originator ÖVE Master TRF dated 00-07 Copyright reserved to the bodies participating in the IECEE Schemes (CB and CB-FCS) and/or the bodies participating in the C.I. G (CCA-ENEC). Test item description Circuit breakers for overcurrent protection for household and similar installation Trademark BONEGA Series PEP-10J Model and/or type reference PEP-10J D 63 (1p)	1 '	ort that was prepared by SGS Fimko Ltd using information obtained
Testing location : 171 02 Praha 71-Troja, Czech Republic Applicant's Name : BONEGA Velkoobchod s.r.o. Address : 696 66 Sudoměřice nad Moravou 302, Czech Republic Test specification Standard : IEC 60898 (2 nd ed):1995 Test procedure : CB Procedure deviation : N/A Non-standard test method : N/A Test Report Form Test Report Form No. : 60898_A/00-12 TRF originator : ÖVE Master TRF : dated 00-07 Copyright reserved to the bodies participating in the IECEE Schemes (CB and CB-FCS) and/or the bodies participating in the C.I. G (CCA-ENEC). Test item description : Circuit breakers for overcurrent protection for household and similar installation Trademark : BONEGA Series : PEP-10J Model and/or type reference : PEP-10J D 63 (1p)	Testing Laboratory Name	Elektrotechnický zkušební ústav
Applicant's Name BONEGA Velkoobchod s.r.o. Address 696 66 Sudoměřice nad Moravou 302, Czech Republic Test specification Standard IEC 60898 (2 nd ed):1995 Test procedure CB Procedure deviation N/A Non-standard test method N/A Test Report Form Test Report Form O 60898_A/00-12 TRF originator ÖVE Master TRF dated 00-07 Copyright reserved to the bodies participating in the IECEE Schemes (CB and CB-FCS) and/or the bodies participating in the C.I.G (CCA-ENEC). Test item description Circuit breakers for overcurrent protection for household and similar installation Trademark BONEGA Series PEP-10J Model and/or type reference PEP-10J D 63 (1p)	Address	Pod Lisem 129
Address	Testing location	171 02 Praha 71-Troja, Czech Republic
Test specification Standard IEC 60898 (2 nd ed):1995 Test procedure CB Procedure deviation N/A Non-standard test method N/A Test Report Form Test Report Form No. 60898_A/00-12 TRF originator ÖVE Master TRF dated 00-07 Copyright reserved to the bodies participating in the IECEE Schemes (CB and CB-FCS) and/or the bodies participating in the C.I.G (CCA-ENEC). Test item description Circuit breakers for overcurrent protection for household and similar installation Trademark BONEGA Series PEP-10J Model and/or type reference PEP-10J D 63 (1p)	Applicant's Name	BONEGA Velkoobchod s.r.o.
Test specification Standard	Address	696 66 Sudoměřice nad Moravou 302, Czech Republic
Standard	:	
Test procedure	Test specification	
Procedure deviation	Standard	IEC 60898 (2 nd ed):1995
Non-standard test method	Test procedure	CB
Test Report Form No	Procedure deviation	N/A
Test Report Form No	Non-standard test method	N/A
TRF originator	Test Report Form	
Master TRF	Test Report Form No	60898A/00-12
Copyright reserved to the bodies participating in the IECEE Schemes (CB and CB-FCS) and/or the bodies participating in the C.I.G (CCA-ENEC). Test item description	TRF originator	ÖVE
participating in the C.I.G (CCA-ENEC). Test item description	Master TRF	dated 00-07
installation Trademark		ipating in the IECEE Schemes (CB and CB-FCS) and/or the bodies
Series	Test item description	
Model and/or type reference PEP-10J D 63 (1p)	Trademark	BONEGA
	Series	PEP-10J
Rating(s)	Model and/or type reference	PEP-10J D 63 (1p)
	Rating(s)	AC 230/400 V, 63 A, 50 Hz

Test items particulars:	
Type of circuit-breaker	for overcurrent protection for household and similar installations
Number of poles	single-pole
Protection against external influences	unenclosed
Method of mounting	panel board
Method of connection	not associated with the mechanical mounting
Instantaneous tripping current	D
Ambient air temperature (°C)	30
Energy limiting class	
Rated short-circuit capacity (A)	10 000
Type of terminal	terminal with stirrup (indirect pressure)
Value of rated operational voltage	230/400 V
Value of rated current	63 A
Value of rated frequency	50 Hz
Test case verdicts	
Test case does not apply to the test object:	N(.A.)
Test item does meet the requirement	P(ass)
Test item does not meet the requirement:	F(ail)
Testing	
Date of receipt of test item	27.01.2005
Date(s) of performance of test	07.02. to 14.02.2005

General remarks

This report shall not be reproduced except in full without the written approval of the testing laboratory.

The test results presented in this report relate only to the item(s) tested.

"(see remark #)" refers to a remark appended to the report.

"(see Annex #)" refers to an annex appended to the report.

Throughout this report a comma is used as the decimal separator.

Copy of marking plate and summary of test results:	
See Annex No:1/1-4 of Test Report No:500097-01/01/1	
Photograph See Annex No:2/1 Test Report No:500097-01/01/1	
	- Autonomore
	ĺ

		IEC 60 898		
CI.	Requirement - Test		Result	Verdict

5.	MARKING AND OTHER INFORMATION			
	Circuit-breaker marked with:			
	a) Manufacturer's name or trade mark	BONEGA	P	
	b)Type designation, catalogue number or other identification number	PEP-10J D 63 (1p)	Р	
	c) Rated voltage (V)	230/400	Р	
	d) Rated current (A)	63	Р	
	e) Rated frequency (Hz)		N	
	f) Rated short circuit capacity (A)	10 000	Р	
	g) Wiring diagram		N	
	h) Ambient air temperature, if different from 30°C (°C)		N	
	Symbol for instantaneous tripping current	D	Р	
	Symbol for nature of supply	~	Р	
	Marking for rated current and for instantaneous tripping shall be readily visible when CB is installed		Р	
	Other marking shall be easily discernible		Р	
	Energy limiting class		N	
	I ² t characteristic (documentation)		N	
	Symbols on supply and load terminal		N	
	Terminal for neutral conductor N		N	
	Earthing terminal if any		N	
	On - off position shall be clearly indicated - 0 I -		Р	
	For push-button CB the off push-button shall either be red or be marked with the symbol '0'		N	
	Red not used for other push-button		N	
	This symbol shall be easily discernible		N	
	For CB with multiple current ratings, the maximum value is marked, the adjusted value indicated without ambiguity		N	
	Marking shall be indelible and easily legible (not on removable parts), 15 s with water, 15 s with hexane (see cf. 8.3)		Р	

7.	REQUIREMENTS FOR CONSTRUCTION AND OPERATION	
7.1.1	General	
7.1.2	Mechanism	

<u></u>	Danisament Tool	Decult	Verdict
CI.	Requirement – Test	Result	
	The moving contact shall be mechanically coupled so that all poles make and break together, whether operated manually or automatically, even if an overload occurs on one pole only		N
	The switched neutral shall close before and open after the protected pole (s)		N
	Neutral pole having adequate making and breaking capacity and CB with independent manual operation: all poles operate together including neutral pole		N
	CB shall have a trip free mechanism		Р
	It shall be possible to switch the CB on and off by hand		Р
	No intermediate position of the contacts		Р
	Position of contacts shall be indicated		Р
	Indication visible from the outside		P
	If the indication is on the actuating means, it shall, when released, automatically take up or stay in the position corresponding to that of the moving contacts; operating means shall have two different rest positions, except that, for automatic operation, a third distinct rest position may be provided		P
	The action of the mechanism shall not be influenced by the position of enclosures		Р
	If the cover is used as a guiding means for push- button, it shall not be possible to remove this button from the outside		N
	Operating means securely fixed, not possible to remove them without a tool		Р
	For the up-down operating means the contacts shall be closed by the up movement.		Р
7.1.3	Clearances [mm]		
	1.between live parts (of the main circuits) which are	>3	Р
_	separated when the CB is in off position: 3 mm		
_	2.between live parts of different polarity:3 mm	~~~	N
	3.between live parts and:		
	- accessible surfaces of operating means: .3 mm	>3	Р
	- screws or other means for fixing covers:3 mm		N
	- surface on which the base is mounted:6 (3) mm	>3	Р
	- screws or other means for fixing the circuit breaker:	>3	Р
	- metal covers or boxes: 6 (3) mm	>3	Р

	IEC 60 898		
Cl.	Requirement – Test	Result	Verdict
	- other accessible metal parts:		N
	- metal frames supporting the base (flush-type):		N
	4. Between metal parts of mechanism and:		
	- accessible metal parts;3 mm		N
	- screws or other means for fixing the circuit breaker:3 mm		N
	- metal frames supporting the base (flush type):		N
7.1.3	Creepage distances [mm]		
	Between parts (of the main circuit) which are separated when the CB is in off position 3 mm	>3	Р
	2.between live parts of different polarity Ui ≤ 250 V		N
	3.between five parts and:		
	- accessible surfaces of operating means: .3 mm	>3	P
	- screws or other means for fixing covers:3 mm	***	N
	- screws or other means for fixing the CB:	>3	Р
	- accessible metal parts:3 mm	>3	Р
	Note: Live parts in auxiliary circuits: in accordance with subclause 411.1.3.3 of IEC-Publ. 364-4-41		
7.1.4	Screws, current-carrying parts and connections		
7.1.4.1	Connections, withstand mechanical stresses occurring in normal use		Ρ.
	Screws for mounting of the CB not of the thread- cutting type		N
	Test according to cl. 8.4:		
	- 10 times (screw Ø / torque Nm)	ØmmNm Ø mm Nm	N
	- 5 times (screw Ø / torque Nm)	Ø 5,0 mm 2,0 Nm	Р
		ØmmNm	
	Plug in connections tested by plugging in and pulling out five times		N
	After test connections have not become loose nor electrical function impaired		Р
7.1.4.2	Screws with a thread of insulating material ensured correct introduction		N

	IEC 60 898		
CI.	Requirement – Test	Result	Verdict
7.1.4.3	Electrical connection: contact pressure not transmitted through insulating material, unless there is sufficient resilience in the metallic parts		Р
	- copper		Р
	- alloy 58% copper for worked cold parts		N
	- alloy 50% copper for other parts		N
	- other metal		Р
7.1.5	Terminals for external conductors		
7.1.5.1	Terminals ensure correct connection of conductors (Test acc. to cl. 8.5)		Р
8.5	Torque Ø 5,0 mm 2,0 Nm ØmmNm ØmmNm max. sect. 25 mm²		Р
8.5.1	Pull test: min sect 10		Р
	noticeably		
8.5.2	min sect 10 _ mm² Torque (2/3)= 1,33 Nm max sect 25 mm²		Р
8.5.3	The conductor shows no damage Nominal cross-section from		P
6.5.3	No of wires 7 Ø of wires 2,14 mm Torque (2/3) = 1,33Nm		
	After the test no wire escaped outside		
7.1.5.2	Terminals allow the connection of conductors of the following cross-sectional areas:		

	IEC 60 898		_
CI.	Requirement – Test	Result	Verdict
	Rated current (A) Range of nominal cross sections to be clamped (mm^2) ≤ 13 1 to 2,5 $> 13 \leq 16$ 1 to 4 $> 16 \leq 25$ 1,5 to 6 $> 25 \leq 32$ 2,5 to 10 $> 32 \leq 50$ 4 to 16 $> 50 \leq 80$ 10 to 25 $> 80 \leq 100$ 16 to 35 $> 100 \leq 125$ 25 to 50		
	It is required that, for current ratings up to and including 50 A terminals are designed to clamp solid conductors as well as rigid stranded conductors; the use of flexible conductors is permitted		
	Nevertheless, it is permitted that terminals for conductors having cross-sections from 1 mm ² up to 6 mm ² are designed to clamp solid conductors only.	10 to 25 mm²	Р
7.1.5.3	Means for clamping the conductors in the terminals not serve to fix any other component (See test sub-clause 8.5)		Р
7.1.5.4	Terminals for $I_N \le 32$ A allow the connection of conductors without special preparation		N
7.1.5.5	Terminals shall have adequate mechanical strength; ISO thread or equivalent (See tests of sub-clause 8.4 and 8.5.1)		Р
7.1.5.6	Clamping of conductor without damage to the conductor (See test of sub-clause 8.5.2)		Р
7.1.5.7	Clamping of conductor between metal surfaces (See tests of sub-clause 8.4 and 8.5.1)		Р
7.1.5.8	Conductor shall not slip-out when the clamping screw or nuts are tightened (See test of subclause 8.5.3)		Р
7.1.5.9	Terminals shall be properly fixed. No work loose when the clamping screws or nuts are tightened or loosened (See test of sub-clause 8.4)		Р
7.1.5.10	Clamping screws or nuts of terminals for protective conductors adequately secured against accidental loosening		N
7.1.5.12	Screws and nuts of terminals for external conductors shall be in engagement with a metal thread, and the screws shall not be of tapping screw type		Р
7.1.6	Non interchangeability		
	Plug-in CB not replaceable by another of the same make but having a higher size number without aid of a tool		N

	IEC 60 898		
CI	Requirement – Test	Result	Verdict
7.2	Protection against electric shock		
	Live parts not accessible in normal use		P
	For CB, other than plug-in type, external parts, other than screws and other means for fixing covers, which are accessible shall be of insulating material		P
	Unless the live parts are within an internal enclosure of insulating material: Lining - reliable fixed, - adequate thickness and - mechanical strength		P
	Inlet openings for cables shall be in insulating material or be provided with bushings or similar devices in insulating material Such device - shall be reliable fixed - shall have adequate mechanical strength		N
	For plug-in CB, external parts, other than screws and other means for fixing covers, which are accessible shall be in insulating material		N
	Metallic operating means insulated from live parts		N
	Metal parts of the mechanism not accessible and insulated from accessible metal parts, metal frames (for flush-type), screws or other means for fixing the base		Р
	Replacement of plug-in CB possible without touching live parts		N
	Lacquer or enamel not considered		N
3.6	Test: Use of test finger for 1 min with a force of 75 N		Р .
7.10	Resistance to heat		
	CB sufficiently resistant to heat		Р
3.14	Test of resistance to heat		
8.14.1	Test:		
	- without removable covers 1 h (100 ± 2) °C		Р
	- removable covers 1 h (70 ± 2) °C		N
	After the test no access to live parts, marking still legible		Р
8.14.2	Ball pressure test for external parts of insulating material (parts retaining live parts in position) T = 125°C Ø of impression ≤ 2 mm	<2 mm	Р

CI.	Requirement - Test	Result			Verdict
8.14.3	Ball pressure test for external parts of insulating material (parts not retaining live parts in position): $T = (70 \pm 2)^{\circ}C$ or $T = 80 ^{\circ}C = (40 \pm 2)^{\circ}C + \text{max. temperature rise of sub-clause } 8.8$ \emptyset of impression $\leq 2 \text{ mm}$		<2 mm		Р
7.11	Resistance to abnormal heat and to fire				
	External parts of insulating material shall not ignite or spread fire under fault or overload conditions				Р
8.15	Resistance to abnormal heat and to fire				
	Glow wire test: No visible flame, no sustained glowing or flames and glowing extinguish within 30 s				P
	- external parts retaining live parts in position(960 ± 15)°C				Р
	- other external parts(650 ± 10)°C				Р
7.12	Resistance to rusting				
	Ferrous parts adequately protected against rusting				Р
8.16	Test of resistance to rusting: (all grease is removed from the parts)				
	 10 min immersed in a 10% solution of ammoniur chloride in water at 20°C 				Р
	- 10 min at 95% humidity at 20°C				Р
	- 10 min at 100°C				Р
	No sign of rust				Р
				_	
	TESTS "B" 3 samples	B1	B2	B3	
7.3	Dielectric properties		_		
	CB shall have adequate dielectric properties:				Р
8.7	Test: 48 h in humidity cabinet 91% to 95%				P
8.7.2	Insulation resistance of the main circuit (DC 500 V)	[MΩ]	[MΩ]	[MΩ]	
	a) In off-position, between the terminals which are electrically connected together when the circuit breaker is in the closed position $\geq 2~M\Omega$	>2	>2	>2	Р
	b) in off-position, between each pole in turn and the others connected together $\geq 2~\text{M}\Omega$				N
	c) in on-position, between all poles connected together and the frame $\geq 5~\text{M}\Omega$	>5	>5	>5	Р
	d) between metal parts of mechanism and the frame $\geq 5~\text{M}\Omega$				N

CI.	Requirement – Test	Result	Verdict
	e) between the frame and metal foil in contact with the inner surface of the internal enclosure or lining of insulating material $\geq 5~\text{M}\Omega$		N
8.7.3	Dielectric strength of the main circuit (acc. cl. 8.7.2)		
	a) 2000 V		Р
	b) 2000 V		N
	c) 2000 V		Р
	d) 2000 V		N
	e) 2500 V		N
8.7.4	Dielectric strength of the auxiliary and control circuits		
	1) Between all the auxiliary or control circuits and the frame U = V		N
	2) Between each part of the auxiliary or control circuits which may be isolated from the other parts of the auxiliary or control circuits and these—other parts connected together U = V [1000 V if Ui ≤ 60 V or 2Ui + 1000 V if Ui > 60 V]		N
7.4	Temperature rise		
	Temperature rise does not exceed the limiting values stated in table V: sect16 mm²		Р
8.8.2	Test current: I _N = 63 A (reach the steady-state value) - Four-pole CB`s: 1) three poles loaded to I _N A 2) one pole and neutral pole loaded to I _N A		P
	Ambient air temperature	19,5°C	
	PartsTemperature rise [K]	[K] [K] [K]	
	Terminals for external connections60	max.49,3 max.49,9 max. 48,9	Р
	External parts liable to be touched during manual operation of the circuit-breaker, including operating means of insulating material and metallic means for coupling of insulating operating means of several poles	max.17,2 max.18,4 max.18,6	Р
· · · · · · · · · · · · · · · · · · ·	External metallic parts of operating means25	M ships	N
	Other external parts, including that face of the circuit-breaker is in direct contact with the mounting surface		N
8.8.5	Measurement of power losses	B1 B2 B3	
-	Power losses do not exceed the values stated in table XI A		Р

	IEC 60 898				
CI.	Requirement – Test	Result			Verdict
	Test current: $I_N = $ 63 A (reach the steady state value)				Р
	Loaded one pole after the other				N
	Table XI A	[W]	[W]	[W]	P
	Rated current I _N (A) Max. power losses per pole (W)				
	$\begin{array}{llllllllllllllllllllllllllllllllllll$	5,4	5,7	5,2	
7.5	Uninterrupted duty				
	Circuit-breakers operate reliable even after long service				Р
8.9	28 day test: sect16 mm²				Р
	28 cycles - 21 h with current I _N =63A - 3 h without current			-	
	During the test no tripping during the last period, temperature rise shall be measured				Р
	Ambient air temperature		22,5°	C.	
	PartsTemperature rise [K]	[K]	[K]	[K]	
	Terminals for external connections60	50,5	49,2	48,9	Р
	The temperature rise does not exceed the value measured during the temperature rise test (subclause 8.8) by more than 15 K				Р
	Test current 1,45 I _N =91,35 A				
	- Tripping within				
	- 1h (≤ 63 A)				Р
	- 2h (> 63 A)				N
	TESTS "C" 3 samples	C1	C2	C3_	
7.7	Mechanical and electrical endurance				
	Circuit-breaker shall be capable to perform an adequate number of cycles with rated current				Р
8.11	Test: Test Voltage230 V Test Current63 A Sect16 mm²				
	4000 operating cycles				
	- I _N ≤ 32 A: 2 s on - 13 s off	HALLA COMPANY STANKS			N

	IEC 60 898		
CI.	Requirement – Test	Result	Verdict
	- I _N > 32 A: 2 s on - 28 s off		Р
	After the test no damage		Р
	Moreover test current2,55 I _N _160,65A		
	Opening time not less 1 s or more than	[s] [s] [s]	
	- 60 s (≤ 32 A)		N
	- 120 s (> 32 A)	44 – 82	Р
	Dielectric strength reduced to 900 V (1500 V acc. IEC 60898)		Р
8.12.11.2	Test at reduced short-circuit currents: Fig. 3		
	Test current:		
	- 500 A	***	N
	- 10 I _N		Р
	Power factor	0,95	
	Prospective current obtained [A]	630	Р
	Sequence: 6-0 and 3-CO	$[kA^2s]$ $[kA^2s]$ $[kA^2s]$	
	$I^2t \leq \underline{\qquad} kA^2s$	$1^2t \le 70 \text{ kA}^2\text{s}$	Р
	- No permanent arcing		Р
	- No flash-over between poles or between poles and frame		Р
	- No blowing of the fuses F and F'		Р
	- Polyethylene foil shows no holes		P
	After the test:		
	Electric strength test:		
	Test voltage 1500 V (see 8.7.2)		
	a)	THE STATE OF THE S	Р
	b)		N
	c)		Р
	d)		N
	e) 2000 V		N

	IEC 60 898				
CI.	Requirement – Test	Result			Verdict
	TESTS "D" 3 samples			_	
7.6	Automatic operation				
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.				Р
8.10	Tests: DO	DO 1	DO 2	DO 3	
	$I_N(A)$		63		
	Sect. (mm²)		16		
	Instantaneous tripping current		D		
8.10.1	Test of time-current characteristic				
8.10.1.1	Test current 1,13 I _N (A) starting from cold for:		71,19 A		
	- 1 h (I _N ≤ 63 A)				Р
	- 2 h (I _N > 63 A)				N
	No tripping				P
	Then steadily increased within 5 s to 1,45 I _N (A)		91,35 A		
	- Tripping within	[min]	[min]	[min]	
	- 1h (≤ 63 A)	33"	30"	34"	P
	- 2h (> 63 A)			_	N
8.10.1.2	Test current 2,55 I _N (A) starting from cold for:		160,65 A		
	opening time not less than 1 s or more than	[s]	[s]	 [s]	
	- 60 s				N
	- 120 s	30	28	29	Р
8.10.2	Test of instantaneous tripping:				
3.10.2.1	□ B - Type				N
	Test current 3I _N (A), starting from cold				
	Opening time:	[s]	[s]	[s]	
	- 0,1s ≤ t ≤ 45s (≤ 32A)				N
	- 0,1s ≤ t ≤ 90s (> 32A)				N
	Test current 5 I _N (A), starting from cold				N
	Tripping less than 0,1 s		_		N
8.10.2.2	☐ C - Type				N
	Test current 5I _N (A), starting from cold				
	Opening time:	[s]	[s]	[s]	
	- 0,1s ≤ t ≤ 15s (≤ 32A)			_	N
	- 0,1s ≤ t ≤ 30s (> 32A)				N
	Test current 10 I _N (A), starting from cold				N
	Tripping less than 0,1 s				N
8.10.2.3	□ D - Type	1	_		Р

	IEC 60 898				
CI.	Requirement – Test	Result			Verdict
	Test current 10I _N (A), starting from cold		630 A		
	Opening time:	[s]	[s]	[s]	
	- 0,1s ≤ t ≤ 4s (≤ 32A)				N
	- 0,1s ≤ t ≤ 8s (> 32A)	6	7	7	Р
	Test current 20 I _N (A), starting from cold		1260 A		
	Tripping less than 0,1 s	0,007	0,008	0,008	Р
8.10.3	Test of effect of single pole loading on the tripping characteristic of multipole circuit-breakers:				N
	Test current 1,1 lt (A), (two pole) starting from cold				
	Tripping within	[min]	[min]	[min]	
	- 1h				N
	- 2h				N
	Test current 1,2 It (A), (three pole or four pole) starting from cold			_	
	Tripping within	[min]	[min]	[min]	
	- 1h				N
	- 2h				N
8.10.4	Test of effect of ambient temperature on the tripping characteristics				
	a) Ambient temperature of (-5 ± 2)°C				Р
	Test current 1,13 I _N (A)		71,19 A		
	- Passed for 1h				P
	- Passed for 2h				N
	Current is then steadily increased to 1,9 I _N (A) within 5s	_	119,7 A		'
	Tripping within	[min]	[min]	[min]	
	- 1h	51"	50"	48"	Р
	- 2h				N
	b) Ambient temperature of (40 ± 2)°C	_			Р
	Test current I _N (A)		63		Р
	No tripping within				
	- 1h		_		Р
	- 2h				N

	Requirement – Test	Result			Verdict
	Tests: D1	D1 ₁	D1 ₂	D1 ₃	10.0.0
7.9	Resistance to mechanical shock and impact	1			
· · ·	CB shall have adequate mechanical behaviour so as to withstand the stresses imposed during installation and use				Р
8.13.1	Mechanical shock				
	- 50 falls on two sides of vertical board C				Р
	- Vertical board turned 90°				Р
	- 50 falls on two sides of vertical board C				Р
	During the test the circuit-breakers shall not open				Р
8.13.2	Mechanical impact				TO THE REAL PROPERTY.
8.13.2.1	All types:				
	- Impact test: 10 blows-height 10 cm, no damage				Р
8.13.2.2	Screw-in types:				N
	- Torque 2,5 Nm for 1 min, no damage				N
8.13.2.3	CB intended to be mounted on a rail and plug-in types:				
	- downward vertical 50 N for 1 min				P
	- upward vertical 50 N for 1 min, no damage				Р
3.12.11.3	Test at 1500 A:				
	Prospective current of 1500 A - power factor 0,93 to 0,98				-
	Prospective current obtained (A)	152	20 A		
	Power factor	0,9	95		
	Test circuit: figure	3			
	T (min)	3 m	in		
	Distance a (mm)	35	mm		
	Sequence	6xO, 2xCO			
	I _{Peak} (A) max. value	22	00 A		
	$I^2t \leq \underline{\qquad} kA^2s$	[kA ² s]	[kA ² s]	[kA ² s]	
		17	13	15	Р
	- No permanent arcing				Р
	- No flash-over between poles or between poles and frame				Р
	- No blowing of the fuses F and F'				Р
	- Polyethylene foil shows no holes				Р
	Electric strength test:				
	Test voltage 1500 V (see 8.7.2)				
	a)				Р

	IEC 60 898		
CI.	Requirement – Test	Result	Verdict
	b)		N
	c)		Р
	d)		N
	e) 2000 V		N
8.12.12	Test current equal to 0,85 times of the conventional non-tripping current (starting from cold)	60,51 A	
	- for 1h		Р
	- for 2h		N
	Steadily increasing within 5s the current to 1,1 times the conventional tripping current = A	100,49 A	
	Tripping within 60 min	min min m	in
		t < 60 min.	Р

	TESTS "E" 3 + 3 samples		
3.12.11.4.2	Test: E1(Test at service short-circuit capacity)	E ₁₋₁ E ₁₋₂ E	1-3
	Service short-circuit capacity	7500 A	
	Test circuit: figure	3	
	Prospective current	7500 A	
	Prospective current obtained	7600 A	
	Power factor	0,5	
	Power factor obtained	0,5	
	Sequence	0-0-00	
	T (min)	3 min	
	Distance a (mm)	35 mm	
	I _{Peak} (A) max. value	13100 A	
	$I^2t \leq \underline{\hspace{1cm}} kA^2s$	$[kA^2s]$ $[kA^2s]$ $[kA^2s]$	\ ² s]
		68 25 18 68 75 65 65 5	66 56 P
	- No permanent arcing		Р
	- No flash-over between poles or between poles and frame		Р
	- No blowing of the fuses F and F'		Р
	- Polyethylene foil shows no holes		Р
_	Electric strength test:		
	Test voltage 1500 V (see 8.7.2)		
	a)		Р
	b)		N
	c)		Р
	d)		N

	IEC 60 898				
CI.	Requirement – Test	Result			Verdict
_	e) 2000 V				N
8.12.12	Test current equal to 0,85 times of the conventional non-tripping current (starting from cold)	6	0,51 A		
	- for 1h				Р
	- for 2h				N
	Steadily increasing within 5s the current to 1,1 times the conventional tripping current (A)	10	00,49 A		J-
	Tripping within 60 min	min	min	min	
			t < 60 mi	n.	P
8.12.11.4.3	Test: E2 (Test at rated short-circuit capacity)	E ₂₋₁	E ₂₋₂	E ₂₋₃	
	Rated short-circuit capacity		10000 A		
	Test circuit: figure	: 5			
	Prospective current				
	Prospective current obtained:	: 10200 A			
	Power factor	0,45-0,5			
	Power factor obtained		0,5		
	Sequence	1xO , 1xCO			
	T (min):				
	Distance a (mm)	35 mm			
	I _{Peak} (A) max. value:	1	5000 A		
	$ ^2t \leq \underline{\qquad} kA^2s$	[kA ² s]	[kA ² s]	[kA ² s]	
		58 56	55 36	47 44	
	- No permanent arcing				Р
	- No flash-over between poles or between poles and frame				Р
	- No blowing of the fuses F and F'				Р
	- Polyethylene foil shows no holes				Р
	Electric strength test:				
	Test voltage 900 V (see 8.7.2)				
	a)				Р
	b)				N
	c)				Р
	d)				N
	e) 2000 V				N
	Test current 2,8 I _N		176,4	A	
	Tripping within > 0,1 s up to	(s)	(s)	(s)	
	- 60 s				N

CI.	Requirement – Test	Result			Verdict
	- 120 s	0,1 s <	t < 120 s	5	Р
8.12.11.4.4	Test: E3 (Test at rated short-circuit capacity on an individual pole)	E ₃₋₁	E ₃₋₂	E ₃₋₃	
	Rated short-circuit capacity on an individual pole I _{CN1}			_ A	
	Test circuit: figure				
	Prospective current			_ A	
	Prospective current obtained			_ A	
_	Power factor				
	Power factor obtained				
	Sequence			_	
	T (min):			min	
	Distance a (mm)			mm	
	I _{Peak} (A) max. value			A	
_	2t ≤ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	
_					N
	- No permanent arcing				N
	- No flash-over between poles or between poles and frame				N
	- No blowing of the fuses F and F'				N
	- Polyethylene foil shows no holes			_	N
	Electric strength test:				N
	Test voltage 900 V (see 8.7.2)				N
	a)				N
	b)				N
	c)		_		N
	d)				N
	e) 2000 V				N
	Test current 2,8 I _N			_ A	N
	Tripping within > 0,1 s up to	(s)	(s)	(s)	N
	-60 s				N
	- 120 s				N

		TEST SEQUENCES
Test sequence	Clause or Sub-clause	Test (or inspection)
A	5 7.1.1 7.1.2 8.3 7.1.3 7.1.6 8.4 8.5 8.6 8.14 8.15 8.16	Marking General Mechanism Indelibility of marking Clearances and creepage distances (internal parts) Clearances and creepage distances (external parts only) Non-interchangeability Reliability of screws, current-carrying parts and connections Reliability of terminals for external conductors Protection against electric shock Resistance to heat Resistance to abnormal heat and to fire Resistance to rusting
В	8.7 8.8 8.9	Dielectric properties Temperature rise 28-day test
C	8.11 8.12.11.2 (and 8.12.12)	Mechanical and electrical endurance Performance at reduced short-circuit currents
D D0	8.10	Tripping characteristic
D D1	8.13 8.12.11.3 (and 8.12.12)	Resistance to mechanical shock and impact Short-circuit performance at 1500 A
E E1	8.12.11.4.3 (and 8.12.12)	Performance at service short-circuit capacity
E E2	8.12.11.4.3 (and 8.12.12)	Performance at rated short-circuit capacity
E E3	8.12.11.4.4 (and 8.12.12)	Performance at rated making and breaking capacity I _{CN1} on an individual pole of multipole circuit breakers
With the agre	eement of the manufacturer the	he same samples may be used for more than one test sequence.

TRF No. 60898_A TRF originator: OVE

TABLECS	REDUCTION OF SAMPLES FOR SERIES OF CIRCUIT-BREAKERS HAVING DIFFERENT
TABLE C.3 -	REDUCTION OF SAMPLES FOR SERIES OF CIRCUIT-BREAKERS HAVING DIFFERENT
	NUMBERS OF POLES


	140MBERO OF TO			
Test sequence	Number of samples depending on number of poles ^{a)}			
	1 pole ^{b)}	2 pole ^{C)}	3 pole d)	4 pole ^{e)}
A	1 maximum rated current	1 maximum rated current g) i)	1 maximum rated current i)	1 maximum rated current i)
В	3 maximum rated current	3 maximum rated current g)	3 maximum rated current	3 maximum rated current
С	3 maximum rated current	3 maximum rated current 9)	3 maximum rated current	3 maximum rated current
D0 + D1	3 maximum rated current	3 maximum rated current h)	3 maximum rated current	3 maximum rated current
D0	1 of all other rated currents			
E1	3 + 3 f) maximum rated current 3 + 3 f) minimum rated current	3 maximum rated current 3 minimum rated current	3 maximum rated current 3 minimum rated current	3 maximum rated current 3 minimum rated current
E2	3 + 4 f) maximum rated current 3 + 4 f) minimum rated current	3 maximum rated current 3 minimum rated current	3 maximum rated current 3 minimum rated current	3 maximum rated current 3 minimum rated current
E3	k)	3 maximum rated current j)	3 maximum rated current j)	3 maximum rated current j)


- a) If a test is to be repeated according to the acceptance criteria of C.2, a new set of samples is used for the relevant test sequence. In repeated tests all results shall be satisfactory.
- b) If only multipole circuit-breakers are submitted, this column applies to the set of samples having the smallest number of poles (instead of the relevant column).
- c) Applicable to two-pole circuit-breakers whether with two protected poles or with one protected pole.
- d) This column does not apply if four-pole circuit-breakers are also tested.
- e) Also applicable to circuit-breakers with three protected poles and a neutral pole.
- f) Supplementary samples in case of single-pole circuit-breakers rated 230/400 V (see table 1).
- g) This test sequence shall be omitted when three-pole or four-pole circuit-breakers have been tested.
- h) This test sequence shall be omitted for two-pole circuit-breakers with two protected poles, when three-pole or four-pole circuit-breakers have been tested.
- i) When multipole circuit-breakers are submitted, a maximum of four screw-type terminals for external conductors are subjected to the tests of 8.5, i.e. two supply and two load terminals.
- j) If each pole of the multipole is identical to the individual pole tested in E2, this test is omitted. If not this test is carried out on an individual protected pole, taken at random, of the circuit-breaker with the highest number of poles.
- k) Covered by test sequence E2

	NUMBER OF SAM	MPLES FOR FULL TEST PROCEDU	IRE
Test sequence	Number of samples	Minimum number of samples which shall pass the tests a) b)	Number of samples for repeated tests c)
A	1	1	-
В	3	2	3
С	3	2 ^e)	3
D	3	2e)	3
E ₁	3+3d)	-	3+3d)
E ₂	3+4 ^d)	2e) + 2d) e) 2e) + 3d) e)	3+4d)
E ₃	3	2e)	3

- a) In total, a maximum of two test sequences may be repeated.
- b) It is assumed that a sample which has not passed a test has not met the requirements due to workmanship or assembly defects which are not representative of the design.
- c) In the case of repeated tests, all test results must be acceptable.
- d) Supplementary samples in the case of single-pole CB having a rated voltage of 230/400 V.
- e) All samples shall meet the test requirements of sub-clause 8.12.10, 8.12.11.2, 8.12.11.3 and 8.12.11.4 as appropriate.


ANNEX 1/1 500097-01/01











500097-01/01


































ANNEX 1/3 500097-01/01





























50/60 Hz


EN 60898


☐ IP 20

50/80 Hz

EN 60898


☐ JP 20





ANNEX 2/1 500097-01/01/1





TEST REPORT

IEC 60 898

Circuit-Breakers for overcurrent protection for household and similar installation

Report reference No	500097-01/01/2
Tested by (printed name and signature)	Jaroslav Klípa Galler
Approved by (printed name and signature)	Jan Hlavatý
Date of issue	14.02.2005
This report is based on a blank test repfrom the TRF originator (see below).	port that was prepared by SGS Fimko Ltd using information obtained
Testing Laboratory Name	Elektrotechnický zkušební ústav
Address	Pod Lisem 129
Testing location	171 02 Praha 71-Troja, Czech Republic
Applicant's Name	BONEGA Velkoobchod s.r.o.
Address	696 66 Sudoměřice nad Moravou 302, Czech Republic
Test specification	
Standard	IEC 60898 (2 nd ed):1995
Test procedure	CB
Procedure deviation	N/A
Non-standard test method	N/A
Test Report Form	
Test Report Form No	60898A/00-12
TRF originator	ÖVE
Master TRF	dated 00-07
Copyright reserved to the bodies partic participating in the C.I.G (CCA-ENEC).	ipating in the IECEE Schemes (CB and CB-FCS) and/or the bodies
Test item description	Circuit breakers for overcurrent protection for household and similar installation
Trademark	BONEGA
Series	PEP-10J
Model and/or type reference	PEP-10J D 63 (4p)
Rating(s)	AC 400 V, 63 A, 50 Hz

Test items particulars:	
Type of circuit-breaker:	for overcurrent protection for household and similar installations
Number of poles	four-pole
Protection against external influences:	unenclosed
Method of mounting	panel board
Method of connection	not associated with the mechanical mounting
Instantaneous tripping current	D
Ambient air temperature (°C)	30
Energy limiting class	
Rated short-circuit capacity (A)	10 000
Type of terminal	terminal with stirrup (indirect pressure)
Value of rated operational voltage	400 V
Value of rated current	63 A
Value of rated frequency	50 Hz
Test case verdicts	
Test case does not apply to the test object:	N(.A.)
Test item does meet the requirement	P(ass)
Test item does not meet the requirement:	F(ail)
Testing	
Date of receipt of test item	27.01.2005
Date(s) of performance of test	07.02. to 14.02.2005

General remarks

This report shall not be reproduced except in full without the written approval of the testing laboratory.

The test results presented in this report relate only to the item(s) tested.

"(see remark #)" refers to a remark appended to the report.

"(see Annex #)" refers to an annex appended to the report.

Throughout this report a comma is used as the decimal separator.

Copy of marking plate and summary of test results:	
See Annex No:1/1-4 of Test Report No:500097-01/01/1	
Photograph See Annex No:2/1 of Test Report No:500097-01/01/1	

	IEC 60 898	
Requirement – Test	Result	Verdict
_		Requirement – Test Result

5.	MARKING AND OTHER INFORMATION			
	Circuit-breaker marked with:			
	a) Manufacturer's name or trade mark:	BONEGA	Р	
	b)Type designation, catalogue number or other identification number	PEP-10J D 63 (4p)	Р	
	c) Rated voltage (V)	400	Р	
	d) Rated current (A)	63	Р	
	e) Rated frequency (Hz)		N	
	f) Rated short circuit capacity (A)	10 000	Р	
	g) Wiring diagram		N	
	h) Ambient air temperature, if different from 30°C (°C)		N	
	Symbol for instantaneous tripping current	D	Р	
	Symbol for nature of supply	~	Р	
	Marking for rated current and for instantaneous tripping shall be readily visible when CB is installed		Р	
	Other marking shall be easily discernible		Р	
	Energy limiting class		N	
	I ² t characteristic (documentation)		N	
	Symbols on supply and load terminal		N	
	Terminal for neutral conductor N		N	
	Earthing terminal if any		N	
	On - off position shall be clearly indicated - 0 I -	_	Р	
	For push-button CB the off push-button shall either be red or be marked with the symbol '0'		N	
	Red not used for other push-button		N	
	This symbol shall be easily discernible		N	
	For CB with multiple current ratings, the maximum value is marked, the adjusted value indicated without ambiguity		N	
	Marking shall be indelible and easily legible (not on removable parts), 15 s with water, 15 s with hexane (see cl. 8.3)		Р	

7.	REQUIREMENTS FOR CONSTRUCTION AND OPERATION	
7.1.1	General	
7.1.2	Mechanism	

	Desir to the Test		
C1.	Requirement – Test	Result	Verdict
	The moving contact shall be mechanically coupled so that all poles make and break together, whether operated manually or automatically, even if an overload occurs on one pole only		P
	The switched neutral shall close before and open after the protected pole (s)		N
	Neutral pole having adequate making and breaking capacity and CB with independent manual operation: all poles operate together including neutral pole		N
	CB shall have a trip free mechanism		Р
	It shall be possible to switch the CB on and off by hand		Р
	No intermediate position of the contacts		Р
	Position of contacts shall be indicated		Р
	Indication visible from the outside		Р
	If the indication is on the actuating means, it shall, when released, automatically take up or stay in the position corresponding to that of the moving contacts; operating means shall have two different rest positions, except that, for automatic operation, a third distinct rest position may be provided		Р
	The action of the mechanism shall not be influenced by the position of enclosures		Р
	If the cover is used as a guiding means for push- button, it shall not be possible to remove this button from the outside		N
	Operating means securely fixed, not possible to remove them without a tool		Р
	For the up-down operating means the contacts shall be closed by the up movement.		Р
7.1.3	Clearances [mm]		
	1.between live parts (of the main circuits) which are	>3	Р
	separated when the CB is in off position: 3 mm		
	2.between live parts of different polarity:3 mm		N
	3.between live parts and:		
	- accessible surfaces of operating means: .3 mm	>3	Р
	- screws or other means for fixing covers:3 mm		N
	- surface on which the base is mounted:6 (3) mm	>3	P
	- screws or other means for fixing the circuit breaker:	>3	Р
	- metal covers or boxes: 6 (3) mm	>3	Р

	IEC 60 898		
CI.	Requirement – Test	Result	Verdict
	- other accessible metal parts:3 mm		N
	- metal frames supporting the base (flush-type):		N
	4. Between metal parts of mechanism and:		
	- accessible metal parts:3 mm		N
	- screws or other means for fixing the circuit breaker:		N
	- metal frames supporting the base (flush type):		N
7.1.3	Creepage distances [mm]		
	Between parts (of the main circuit) which are separated when the CB is in off position 3 mm	>3	Р
	2.between live parts of different polarity Ui ≤ 250 V	>4	Р
	3.between live parts and:		
	- accessible surfaces of operating means: .3 mm	>3	P
	- screws or other means for fixing covers:3 mm	P	N
	- screws or other means for fixing the CB: 6 (3) mm	>3	Р
	- accessible metal parts:3 mm	>3	Р
	Note: Live parts in auxiliary circuits: in accordance with subclause 411.1.3.3 of IEC-Publ. 364-4-41		
7.1.4	Screws, current-carrying parts and connections		
7.1.4.1	Connections, withstand mechanical stresses occurring in normal use		Р
	Screws for mounting of the CB not of the thread- cutting type		N
	Test according to cl. 8.4:		
	- 10 times (screw Ø / torque Nm)	ØmmNm	N
		Ø mm Nm	
	- 5 times (screw Ø / torque Nm)	Ø 5,0 mm 2,0 Nm	Р
		ØmmNm	
-	Plug in connections tested by plugging in and pulling out five times		N
	After test connections have not become loose nor electrical function impaired		Р
7.1.4.2	Screws with a thread of insulating material ensured correct introduction		N

	IEC 60 898		
CI.	Requirement – Test	Result	Verdict
7.1.4.3	Electrical connection: contact pressure not transmitted through insulating material, unless there is sufficient resilience in the metallic parts		Р
	- copper		Р
	- alloy 58% copper for worked cold parts		N
	- alloy 50% copper for other parts		N
	- other metal		Р
7.1.5	Terminals for external conductors		
7.1.5.1	Terminals ensure correct connection of conductors (Test acc. to cl. 8.5)		Р
8.5	Torque Ø 5,0 mm 2,0 Nm ØmmNm ØmmNm max. sect. 25 mm²		Р
8.5.1	Pull test: min sect 10		Р
8.5.2	min sect 10 _ mm² Torque (2/3)= 1,33 Nm max sect 25 mm² The conductor shows no damage		Р
8.5.3	Nominal cross-section from1 to25 mm² No of wires7 Ø of wires2,14 mm Torque (2/3) =1,33Nm After the test no wire escaped outside		P
7.1.5.2	Terminals allow the connection of conductors of the following cross-sectional areas:		

IEC 60 898 CI. Requirement - Test Result Verdict Range of nominal cross Rated current sections to be clamped (A) (mm²) 2.5 ≤ 13 to > 13 < 16 1 to 4 > 16 ≤ 25 6 1.5 to > 25 ≤ 32 2.5 to 10 > 32 < 50 16 4 to > 50 < 80 10 25 to > 80 ≤ 100 35 16 to > 100 ≤ 125 25 50 It is required that, for current ratings up to and including 50 A terminals are designed to clamp solid conductors as well as rigid stranded conductors; the use of flexible conductors is permitted P Nevertheless, it is permitted that terminals for conductors having cross-sections from 1 mm² up to 6 mm² are designed to clamp solid conductors 10 to 25 mm² 7.1.5.3 Means for clamping the conductors in the P terminals not serve to fix any other component (See test sub-clause 8.5) 7.1.5.4 Ν Terminals for $I_N \le 32$ A allow the connection of conductors without special preparation Р 7.1.5.5 Terminals shall have adequate mechanical strength; ISO thread or equivalent (See tests of sub-clause 8.4 and 8.5.1) Clamping of conductor without damage to the 7.1.5.6 conductor (See test of sub-clause 8.5.2) 7.1.5.7 Clamping of conductor between metal surfaces Ρ (See tests of sub-clause 8.4 and 8.5.1) Conductor shall not slip-out when the clamping Р 7.1.5.8 screw or nuts are tightened (See test of subclause 8.5.3) Ρ 7.1.5.9 Terminals shall be properly fixed. No work loose when the clamping screws or nuts are tightened or loosened (See test of sub-clause 8.4) 7.1.5.10 Clamping screws or nuts of terminals for Ν protective conductors adequately secured against accidental loosening Screws and nuts of terminals for external Ρ 7.1.5.12 conductors shall be in engagement with a metal thread, and the screws shall not be of tapping screw type 7.1.6 Non interchangeability Plug-in CB not replaceable by another of the same make but having a higher size number

without aid of a tool

IEC 60 898 CI. Result Verdict Requirement - Test 7.2 Protection against electric shock Live parts not accessible in normal use For CB, other than plug-in type, external parts, Ρ other than screws and other means for fixing covers, which are accessible shall be of insulating material Р Unless the live parts are within an internal enclosure of insulating material: Lining - reliable fixed. - adequate thickness and - mechanical strength Inlet openings for cables shall be in insulating Ν material or be provided with bushings or similar devices in insulating material Such device - shall be reliable fixed - shall have adequate mechanical strength Ν For plug-in CB, external parts, other than screws and other means for fixing covers, which are accessible shall be in insulating material Metallic operating means insulated from live parts Ν Р Metal parts of the mechanism not accessible and insulated from accessible metal parts, metal frames (for flush-type), screws or other means for fixing the base Ν Replacement of plug-in CB possible without touching live parts Lacguer or enamel not considered Ν Ρ 8.6 Use of test finger for 1 min with a force of 75 N 7.10 Resistance to heat CB sufficiently resistant to heat Р Test of resistance to heat 8.14 8.14.1 Test: Ρ - without removable covers...... 1 h (100 ± 2) °C Ν - removable covers 1 h (70 ± 2) °C Р After the test no access to live parts, marking still legible Ball pressure test for external parts of insulating Ρ 8.14.2 <2 mm material (parts retaining live parts in position) $T = 125^{\circ}C$ \emptyset of impression $\leq 2 \text{ mm}$

	IEC 60 898		
CI.	Requirement – Test	Result	Verdict
8.14.3	Ball pressure test for external parts of insulating material (parts not retaining live parts in position): $T = (70 \pm 2)^{\circ}C$ or $T = 80 ^{\circ}C = (40 \pm 2)^{\circ}C + \text{max. temperature rise of sub-clause } 8.8$ \emptyset of impression $\leq 2 \text{ mm}$	<2 mm	Р
7.11	Resistance to abnormal heat and to fire		
	External parts of insulating material shall not ignite or spread fire under fault or overload conditions		Р
8.15	Resistance to abnormal heat and to fire		
	Glow wire test: No visible flame, no sustained glowing or flames and glowing extinguish within 30 s		Р
	- external parts retaining live parts in position (960 ± 15)°C		Р
	- other external parts(650 ± 10)°C		P
7.12	Resistance to rusting		
	Ferrous parts adequately protected against rusting		Р
8.16	Test of resistance to rusting: (all grease is removed from the parts)		
	 10 min immersed in a 10% solution of ammonium chloride in water at 20°C 		Р
	- 10 min at 95% humidity at 20°C		Р
	- 10 min at 100°C		Р
	No sign of rust		Р

	TESTS "B" 3 samples	В1	B2	В3	
7.3	Dielectric properties				
	CB shall have adequate dielectric properties:				P
8.7	Test: 48 h in humidity cabinet 91% to 95%				Р
8.7.2	Insulation resistance of the main circuit (DC 500 V)	- [MΩ]	[MΩ]	[ΜΩ]	
	a) In off-position, between the terminals which are electrically connected together when the circuit breaker is in the closed position $\geq 2~\text{M}\Omega$	>2	>2	>2	Р
	b) in off-position, between each pole in turn and the others connected together $\geq 2~M\Omega$				N
	c) in on-position, between all poles connected together and the frame $\geq 5~M\Omega$	>5	>5	>5	Р
	d) between metal parts of mechanism and the frame \geq 5 $M\Omega$				N

Report ref. No.: 500097-01/01/2 IEC 60 898 Result CI. Requirement - Test Verdict e) between the frame and metal foil in contact with the inner surface of the internal enclosure or lining of insulating material $\geq 5 \text{ M}\Omega$ 8.7.3 Dielectric strength of the main circuit (acc. cl. 8.7.2) Р a) 2000 V Р b) 2000 V Р c) 2000 V d) 2000 V Ν e) 2500 V 8.7.4 Dielectric strength of the auxiliary and control 1) Between all the auxiliary or control circuits and Ν the frame U ≈ ____ V 2) Between each part of the auxiliary or control Ν circuits which may be isolated from the other parts of the auxiliary or control circuits and these other parts connected together U = V [1000 V if Ui ≤ 60 V or 2Ui + 1000 V if Ui > 60 V] 7.4 Temperature rise Temperature rise does not exceed the limiting values stated in table V: sect. _____16 mm² 8.8.2 Test current: I_N= 63 A (reach the steady-state value) - Four-pole CB's: 1) three poles loaded to I_N _____--- A 2) one pole and neutral pole loaded to I_N --- A 19.5°C Ambient air temperature Parts.....Temperature rise [K] [K] [K] [K] max.49.5 max.50 max.49,8 External parts liable to be touched during manual max.18,2 max.20,4 max.19,9 Р operation of the circuit-breaker, including operating means of insulating material and metallic means for coupling of insulating operating means of several poles......40 Ν External metallic parts of operating means......25 Other external parts, including that face of the Ν circuit-breaker is in direct contact with the mounting surface60 8.8.5 Measurement of power losses B2 **B**3 Power losses do not exceed the values stated in Ρ

table XI A

	IEC 60 898				
CI.	Requirement – Test	Result			Verdict
	Test current: I _N =63 A (reach the steady state value)			Р	
	Loaded one pole after the other				N
_	Table XI A	[W]	[W]	[W]	Р
	Rated current I _N (A) Max. power losses per pole (W)				
	$\begin{array}{llllllllllllllllllllllllllllllllllll$	5,1-6,1	5,4-6,1	5,2-6,3	
7.5	Uninterrupted duty				
	Circuit-breakers operate reliable even after long service				Р
8.9	28 day test: sect16 mm²				P
	28 cycles - 21 h with current I _N =63A - 3 h without current				
	During the test no tripping during the last period, temperature rise shall be measured				P
	Ambient air temperature		22,5 C		
	PartsTemperature rise [K]	[K]	[K]	[K]	
	Terminals for external connections60	51,1-53,2	53,2-54,4	50,1-52,2	Р
	The temperature rise does not exceed the value measured during the temperature rise test (subclause 8.8) by more than 15 K				Ρ
	Test current 1,45 I _N =91,35 A				
	- Tripping within				
	- 1h (≤ 63 A)				Р
	- 2h (> 63 A)				N
	TESTS "C" 3 samples	C1	C2	C3	
7.7	Mechanical and electrical endurance				
	Circuit-breaker shall be capable to perform an adequate number of cycles with rated current				Р
8.11	Test: Test Voltage230 V Test Current63 A Sect16 mm²				
	4000 operating cycles				
	- I _N ≤ 32 A: 2 s on - 13 s off				N

	IEC 60 898		
CI.	Requirement – Test	Result	Verdict
	- I _N > 32 A: 2 s on - 28 s off		Р
	After the test no damage		Р
	Moreover test current2,55 I _N _160,65A		
	Opening time not less 1 s or more than	[s] [s] [s]	
	- 60 s (≤ 32 A)		N
	- 120 s (> 32 A)	1s < t < 120 s	Р
	Dielectric strength reduced to 900 V (1500 V acc. IEC 60898)		Р
8.12.11.2	Test at reduced short-circuit currents: Fig. 3		
	Test current:		
	- 500 A		N
	- 10 I _N		Р
	Power factor	0,95	
	Prospective current obtained [A]	630	P
	Sequence: 6-0 and 3-CO	$[kA^2s]$ $[kA^2s]$ $[kA^2s]$	
	$I^2t \leq \underline{\qquad} kA^2s$	$I^2t \leq 70 \text{ kA}^2\text{s}$	Р
	- No permanent arcing		Р
	- No flash-over between poles or between poles and frame		P
	- No blowing of the fuses F and F'		Р
	- Polyethylene foil shows no holes		P
	After the test:		
	Electric strength test:		
	Test voltage 1500 V (see 8.7.2)		
	a)		Р
	b)		Р
	c)		Р
	d)		N
	e) 2000 V		N

	Page 15 of 22		Report re	ef. No.: 50	00097-01/0
	IEC 60 898				
CI.	Requirement – Test	Result			Verdict
	Test current 10I _N (A), starting from cold		630 A		
	Opening time:	[s]	[s]	[s]	
	- 0,1s ≤ t ≤ 4s (≤ 32A)				N
	- 0,1s ≤ t ≤ 8s (> 32A)	6	8	7	Р
	Test current 20 I _N (A), starting from cold		1260 A		
	Tripping less than 0,1 s	0,007	0,006	0,007	Р
8.10.3	Test of effect of single pole loading on the tripping characteristic of multipole circuit-breakers:				N
	Test current 1,1 lt (A), (two pole) starting from cold				
	Tripping within	[min]	[min]	[min]	
	- 1h				N
	- 2h			_	N
	Test current 1,2 lt (A), (three pole or four pole) starting from cold		109,6 A		
	Tripping within	[min]	[min]	[min]	
	- 1h	32"	30"	29"	Р
	- 2h		_		N
8.10.4	Test of effect of ambient temperature on the tripping characteristics				
	a) Ambient temperature of (-5 ± 2)°C				P
	Test current 1,13 I _N (A)	_	71,19 A		
	- Passed for 1h				Р
	- Passed for 2h				N
	Current is then steadily increased to 1,9 I_N (A) within 5s		119,7 A		
	Tripping within	[min]	[min]	[min]	
	- 1h	52"	48"	47"	Р
	- 2h				N
	b) Ambient temperature of (40 ± 2)°C				Р
	Test current I _N (A)		63		Р
	No tripping within				

- 1h

~ 2h

Ρ

Ν

CI.	Requirement – Test	Result	Verdict	
<u></u>	<u> </u>		verdict	
	Tests: D1	D1 ₁ D1 ₂ D1 ₃		
7.9	Resistance to mechanical shock and impact			
_	CB shall have adequate mechanical behaviour so as to withstand the stresses imposed during installation and use		Р	
8.13.1	Mechanical shock			
	- 50 falls on two sides of vertical board C		Р	
	- Vertical board turned 90°			
	- 50 falls on two sides of vertical board C		Р	
	During the test the circuit-breakers shall not open			
8.13.2	Mechanical impact			
8.13.2.1	All types:			
	- Impact test: 10 blows-height 10 cm, no damage		Р	
8.13.2.2	Screw-in types:		N	
	- Torque 2,5 Nm for 1 min, no damage		N	
8.13.2.3	CB intended to be mounted on a rail and plug-in types:			
	- downward vertical 50 N for 1 min		Р	
	- upward vertical 50 N for 1 min, no damage		Р	
8.12.11.3	Test at 1500 A:			
	Prospective current of 1500 A - power factor 0,93 to 0,98		-	
	Prospective current obtained (A)	1540-1560-1520 A		
	Power factor	0,95		
	Test circuit: figure	3		
	T (min)	3 min		
	Distance a (mm)	35 mm		
	Sequence	6xO, 3xCO		
	I _{Peak} (A) max. value	2800-3100-2200 A		
	$I^2t \leq \underline{\hspace{1cm}} kA^2s$	[kA ² s] [kA ² s] [kA ² s]		
		10-26 10-30 8-31	Р	
	- No permanent arcing		Р	
	- No flash-over between poles or between poles and frame		Р	
	- No blowing of the fuses F and F'		Р	
	- Polyethylene foil shows no holes		Р	
	Electric strength test:			
	Test voltage 1500 V (see 8.7.2)			
	(a)		P	

	IEC 60 898		
CI.	Requirement – Test	Result	Verdict
	b)		Р
	c)		P
	d)		N
	e) 2000 V		N
8,12.12	Test current equal to 0,85 times of the conventional non-tripping current (starting from cold)	60,51 A	
	- for 1h		P
	- for 2h		N
	Steadily increasing within 5s the current to 1,1 times the conventional tripping current = A	100,49 A	
	Tripping within 60 min	min min min	
		t < 60 min.	Р

	TESTS "E" 3 + 3 samples				
8.12.11.4.2	Test: E1(Test at service short-circuit capacity)	E ₁₋₁	E ₁₋₂	E ₁₋₃	
	Service short-circuit capacity		7500 A		
	Test circuit: figure		6		
	Prospective current		7500 A		
	Prospective current obtained	7500-	7600-7500) A	
	Power factor		0,5		
	Power factor obtained		0,5		
	Sequence		0-C0-C	0	
	T (min)		3 min		
	Distance a (mm)		35 mm		
	I _{Peak} (A) max. value				
	$ ^2t \le \underline{\hspace{1cm}} kA^2s$	[kA ² s]	[kA ² s]	[kA ² s]	
		16-68	10-69	23-69	Р
	- No permanent arcing				Р
	- No flash-over between poles or between poles and frame				Р
	- No blowing of the fuses F and F'				Р
	- Polyethylene foil shows no holes				Р
	Electric strength test:				
_	Test voltage 1500 V (see 8.7.2)				
_	a)				Р
	b)				Р
_	c)				Р
	d)				N

CI.	Requirement – Test	Result			Verdict
	e) 2000 V		- <u>-</u> -		N
8.12.12	Test current equal to 0,85 times of the conventional non-tripping current (starting from cold)	60,51 A			
	- for 1h				P
	- for 2h			_	N
	Steadily increasing within 5s the current to 1,1 times the conventional tripping current (A)	10	0,49 A		
	Tripping within 60 min	min	min	min	
		t	< 60 min.		
8.12.11.4.3	Test: E2 (Test at rated short-circuit capacity)	E ₂₋₁	E ₂₋₂	E ₂₋₃	
	Rated short-circuit capacity	1	0000 A		
	Test circuit: figure		5	_	
	Prospective current	1	0000 A		
	Prospective current obtained:	10200-10300-10200 A		200 A	
	Power factor		0,5		~~
	Power factor obtained		0,5		
	Sequence	1xO	, 1xCO		
	T (min)		3 min		-~
	Distance a (mm)			_	
	I _{Peak} (A) max. value:				
	$I^2t \leq \underline{\qquad} kA^2s$	$[kA^2s]$ $[kA^2s]$ $[kA^2s]$			
		28-276	14-182	11-190	
	- No permanent arcing				Р
_	 No flash-over between poles or between poles and frame 				Р
	- No blowing of the fuses F and F'				Р
	- Polyethylene foil shows no holes				Р
	Electric strength test:				
	Test voltage 900 V (see 8.7.2)				
	a)				P
	b)				Р
	c)				Р
	d)				N
	e) 2000 V				N
	Test current 2,8 I _N		176,4 A		
	Tripping within > 0,1 s up to	(s)	(s)	(s)	
	- 60 s				N

 CI.	Requirement – Test	Result			Verdict
<u> </u>	- 120 s		s < t < 60) min	P
	- 120 5	0.1	3 11 100	, 11 () 1.	,
8.12.11.4.4	Test: E3 (Test at rated short-circuit capacity on an individual pole)	E ₃₋₁	E ₃₋₂	E ₃₋₃	
	Rated short-circuit capacity on an individual pole I _{CN1}			_ A	
	Test circuit: figure.				
	Prospective current			_ A	
	Prospective current obtained			_ A	
	Power factor				
	Power factor obtained				
	Sequence				
	T (min)			min	
	Distance a (mm)			mm	
	I _{Peak} (A) max. value			_ A	
	$ ^2t \leq \underline{\qquad} kA^2s $	[kA ² s]	[kA ² s]	[kA ² s]	
				_	N
-	- No permanent arcing				N
	- No flash-over between poles or between poles and frame				N
	- No blowing of the fuses F and F'				N
	- Polyethylene foil shows no holes			_	N
	Electric strength test:				N
	Test voltage 900 V (see 8.7.2)				N
	a)				N
	b)				N
	c)				N
	d)				N
	e) 2000 V				N
	Test current 2,8 I _N			_ A	N
	Tripping within > 0,1 s up to	(s)	(s)	(s)	N
	- 60 s				N
	- 120 s				N

		TEST SEQUENCES
Test sequence	Clause or Sub-clause	Test (or inspection)
A	5 7.1.1 7.1.2 8.3 7.1.3 7.1.6 8.4 8.5 8.6 8.14 8.15 8.16	Marking General Mechanism Indelibility of marking Clearances and creepage distances (internal parts) Clearances and creepage distances (external parts only) Non-interchangeability Reliability of screws, current-carrying parts and connections Reliability of terminals for external conductors Protection against electric shock Resistance to heat Resistance to abnormal heat and to fire Resistance to rusting
В	8.7 8.8 8.9	Dielectric properties Temperature rise 28-day test
С	8.11 8.12.11.2 (and 8.12.12)	Mechanical and electrical endurance Performance at reduced short-circuit currents
D D0	8.10	Tripping characteristic
D D1	8.13 8.12.11.3 (and 8.12.12)	Resistance to mechanical shock and impact Short-circuit performance at 1500 A
E E1	8.12.11.4.3 (and 8.12.12)	Performance at service short-circuit capacity
E E2	8.12.11.4.3 (and 8.12.12)	Performance at rated short-circuit capacity
E E3	8.12.11.4.4 (and 8.12.12)	Performance at rated making and breaking capacity I _{CN1} on an individual pole of multipole circuit breakers
With the agree	eement of the manufacture	er the same samples may be used for more than one test sequence.

TABLE C.3 -	REDUCTION OF SAMPLES FOR SERIES OF CIRCUIT-BREAKERS HAVING DIFFERENT
	NUMBERS OF POLES

	TOMBERO OF TOE			
Test sequence	Number of samples de	pending on number of p	oles a)	
	1 pole ^{b)}	2 pole ^{c)}	3 pole d)	4 pole ^{e)}
А	1 maximum rated current	1 maximum rated current g) i)	1 maximum rated current i)	1 maximum rated current i)
В	3 maximum rated current	3 maximum rated current g)	3 maximum rated current	3 maximum rated current
С	3 maximum rated current	3 maximum rated current 9)	3 maximum rated current	3 maximum rated current
D0 + D1	3 maximum rated current	3 maximum rated current h)	3 maximum rated current	3 maximum rated current
D0	1 of all other rated currents			
E1	3 + 3 ^{f)} maximum rated current 3 + 3 ^{f)} minimum rated current	3 maximum rated current 3 minimum rated current	3 maximum rated current 3 minimum rated current	3 maximum rated current 3 minimum rated current
E2	3 + 4 ^{f)} maximum rated current 3 + 4 ^{f)} minimum rated current	3 maximum rated current 3 minimum rated current	3 maximum rated current 3 minimum rated current	3 maximum rated current 3 minimum rated current
E3	k)	3 maximum rated current j)	3 maximum rated current j)	3 maximum rated current j)

- a) If a test is to be repeated according to the acceptance criteria of C.2, a new set of samples is used for the relevant test sequence. In repeated tests all results shall be satisfactory.
- b) If only multipole circuit-breakers are submitted, this column applies to the set of samples having the smallest number of poles (instead of the relevant column).
- c) Applicable to two-pole circuit-breakers whether with two protected poles or with one protected pole.
- d) This column does not apply if four-pole circuit-breakers are also tested.
- e) Also applicable to circuit-breakers with three protected poles and a neutral pole.
- f) Supplementary samples in case of single-pole circuit-breakers rated 230/400 V (see table 1).
- g) This test sequence shall be omitted when three-pole or four-pole circuit-breakers have been tested.
- h) This test sequence shall be omitted for two-pole circuit-breakers with two protected poles, when three-pole or four-pole circuit-breakers have been tested.
- i) When multipole circuit-breakers are submitted, a maximum of four screw-type terminals for external conductors are subjected to the tests of 8.5, i.e. two supply and two load terminals.
- j) If each pole of the multipole is identical to the individual pole tested in E2, this test is omitted. If not this test is carried out on an individual protected pole, taken at random, of the circuit-breaker with the highest number of poles.
- k) Covered by test sequence E2

	NUMBER OF SAI	MPLES FOR FULL TEST PROCEDU	IRE
Test sequence	Number of samples	Minimum number of samples which shall pass the tests ^{a) b)}	Number of samples for repeated tests ^{c)}
А	1	1	- 2 2 3
В	3	2	3
С	3	2 ^e)	3
D	3	2 ^e)	3
E ₁	3+3d)	-	3+3d)
E ₂	3+4d)	2e) + 2d) e) 2e) + 3d) e)	3+4 ^d)
E ₃	3		3

- a) In total, a maximum of two test sequences may be repeated.
- b) It is assumed that a sample which has not passed a test has not met the requirements due to workmanship or assembly defects which are not representative of the design.
- c) In the case of repeated tests, all test results must be acceptable.
- d) Supplementary samples in the case of single-pole CB having a rated voltage of 230/400 V.
- e) All samples shall meet the test requirements of sub-clause 8.12.10, 8.12.11.2, 8.12.11.3 and 8.12.11.4 as appropriate.

TEST REPORT

IEC 60 898

Circuit-Breakers for overcurrent protection for household and similar installation

Report reference No	500097-01/01/3
Tested by (printed name and signature):	Jaroslav Klipa Kle ful
Approved by (printed name and signature)	Jan Hlavatý
Date of issue	14.02.2005
This report is based on a blank test report t TRF originator (see below).	hat was prepared by SGS Fimko Ltd using information obtained from the
Testing Laboratory Name	Elektrotechnický zkušební ústav
Address	Pod Lisem 129
Testing location	171 02 Praha 71-Troja, Czech Republic
Applicant's Name	BONEGA Velkoobchod s.r.o.
Address	696 66 Sudoměřice nad Moravou 302, Czech Republic
Test specification	
Standard	IEC 60898 (2 nd ed):1995
Test procedure	CB
Procedure deviation	N/A
Non-standard test method	N/A
Test Report Form	
Test Report Form No	60898A/00-12
TRF originator	ÖVE
Master TRF	dated 00-07
Copyright reserved to the bodies participat participating in the C.I.G (CCA-ENEC).	ing in the IECEE Schemes (CB and CB-FCS) and/or the bodies
Test item description	Circuit breakers for overcurrent protection for household and similar installation
Trademark	BONEGA
Series	PEP-10J
Model and/or type reference	PEP-10J D I (Ip)
Rating(s)	AC 230/400 V, 1 A, 50 Hz

Test items particulars:	
,	6
	for overcurrent protection for household and similar installations
Number of poles:	single-pole
Protection against external influences:	unenclosed
Method of mounting:	panel board
Method of connection:	not associated with the mechanical mounting
Instantaneous tripping current:	D
Ambient air temperature (°C)	30
Energy limiting class:	
Rated short-circuit capacity (A):	10 000
Type of terminal:	terminal with stirrup (indirect pressure)
Value of rated operational voltage:	230/400 V
Value of rated current:	I A
Value of rated frequency:	50 Hz
Test case verdicts	
Test case does not apply to the test object:	N(.A.)
Test item does meet the requirement:	P(ass)
Test item does not meet the requirement:	F(ail)
Testing	
Date of receipt of test item	27.01.2005
Date(s) of performance of test:	07.02. to 14.02.2005

General remarks


This report shall not be reproduced except in full without the written approval of the testing laboratory.

The test results presented in this report relate only to the item(s) tested.

"(see remark #)" refers to a remark appended to the report.

"(see Annex #)" refers to an annex appended to the report.

Throughout this report a comma is used as the decimal separator.



	IEC 60 898					
	TESTS "D" 3 samples					
7.6	Automatic operation					
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.				P	
8.10	Tests: DO	DO 1	DO 2	DO 3		
	I _N (A)		1			
	Sect. (mm²)		2,5			
	Instantaneous tripping current		D			
8.10.1	Test of time-current characteristic					
8.10.1.1	Test current 1,13 I _N (A) starting from cold for:		1,13 A			
	- 1 h (I _N ≤ 63 A)				Р	
	- 2 h (I _N > 63 A)				N	
	No tripping				Р	
	Then steadily increased within 5 s to 1,45 I _N (A)		1,45 A		**	
	- Tripping within	[min]	[min]	[min]		
	- 1h (≤ 63 A)	18"			Р	
	- 2h (> 63 A)				N	
8.10.1.2	Test current 2,55 I_N (A) starting from cold for:	current 2,55 I _N (A) starting from cold for: 2,55 A				
	opening time not less than 1 s or more than	[s]	[s]	[s]		
	-60 s	28"			Р	
	- 120 s				N	
8.10.2	Test of instantaneous tripping:					
8.10.2.1	□ B - Type				N	
	Test current 3I _N (A), starting from cold					
	Opening time:	[s]	[s]	[s]		
	0,1s ≤ t ≤ 45s (≤ 32A)				N	
	- 0,1s ≤ t ≤ 90s (> 32A)				Ν	
	Test current 5 I _N (A), starting from cold				N	
	Tripping less than 0,1 s			200000	N	
8.10.2.2	□ C - Type				N	
	Test current SI_N (A), starting from cold					
	Opening time:	[s]	[s]	[s]	-	
94 Tab of a	- 0,1s ≤ t ≤ 15s (≤ 32A)				N	
	- 0,1s ≤ t ≤ 30s (> 32A)				N	
	Test current 10 I _N (A), starting from cold				N	
	Tripping less than 0,1 s				N	
8.10.2.3	□ D - Type				P	
	Test current 10I _N (A), starting from cold	2940	10 A		-	
	Opening time:	[s]	[s]	[s]	_	

Page 5 of 7

	IEC 60 898		
	- 0,1s ≤ t ≤ 4s (≤ 32A)	8 "	Р
	- 0,1s ≤ t ≤ 8s (> 32A)		N
_	Test current 20 I _N (A), starting from cold	20 A	
	Tripping less than 0,1 s	0,007"	Р
8.10.3	Test of effect of single pole loading on the tripping characteristic of multipole circuit-breakers:		N
	Test current 1,1 It (A), (two pole) starting from cold		
	Tripping within	[min] [min] [min]	
	- 1h		N
	- 2h		N
	Test current 1,2 It (A), (three pole or four pole) starting from cold		
	Tripping within	[min] [min] [min]	
	- 1h		N
enie we	- 2h		N
8.10.4	Test of effect of ambient temperature on the tripping characteristics		
	a) Ambient temperature of (-5 ± 2)°C		P
	Test current 1,13 I _N (A)	1,13 A	
	- Passed for 1h		Р
	- Passed for 2h		N
	Current is then steadily increased to 1,9 l _N (A) within 5s	1,9 A	
	Tripping within	[min] [min] [min]	
	- 1h	55"	P
	- 2h		N
	b) Ambient temperature of (40 ± 2)°C		Р
	Test current I _N (A)	1	Р
	No tripping within		
	- 1h		Р
	- 2h		N

	TESTS "E" 3 + 3 samples		- Linkshood		
8.12.11.4.2	Test: E1(Test at service short-circuit capacity)	E ₁₋₁	E ₁₋₂	E ₁₋₃	
	Service short-circuit capacity		7500 A		
	Test circuit: figure		3		
	Prospective current		7500 A		
	Prospective current obtained		7500 A		
_	Power factor	0,5			
	Power factor obtained	0,5			
	Sequence ::		0-0-C0		
	T (min)		3 min		
	Distance a (mm)		35 mm		
	I _{Peak} (A) max. value				
	$I^2t \leq \underline{\hspace{1cm}} kA^2s$	[A ² s]	[A ² s]	[A ² s]	
	511-222-118 49-592-471 590-380-491		590-380-491	P	
	- No permanent arcing				Р
	- No flash-over between poles or between poles and frame		- Common of the		P
	- No blowing of the fuses F and F'				Р
	- Polyethylene foil shows no holes	_			Р
	Electric strength test:				
	Test voltage 1500 V (see 8.7.2)				
	a)				Р
	b)				N
	c)				Р
	d)				N
	e) 2000 V				N
8.12.12	Test current equal to 0,85 times of the conventional non-tripping current (starting from cold)	0),96 A		
	- for 1h				P
	- for 2h				N
	Steadily increasing within 5s the current to 1,1 times the conventional tripping current (A)	1	,6 A		
	Tripping within 60 min	min	min	min	
			t < 60 min.		P
8.12.11.4.3	Test: E2 (Test at rated short-circuit capacity)	E ₂₋₁	E ₂₋₂	E ₂₋₃	
	Rated short-circuit capacity		10000 A		
	Test circuit: figure	-			
	Prospective current				
	Prospective current obtained		10200 A		

	IEC 60 898			
	Power factor	0,5		
	Power factor obtained	0,5		
	Sequence	1xO , 1xCC)	
	T (min)	3 min		
	Distance a (mm)	35 mm		
	I _{Peak} (A) max. value			
	$I^2t \leq \underline{\qquad} kA^2s$	$[A^2s]$ $[A^2s]$	[A ² s]	
		max 498 max 614	max 616	
	- No permanent arcing			Р
	- No flash-over between poles or between poles and frame			Р
	- No blowing of the fuses F and F'			Р
	- Polyethylene foil shows no holes			Р
	Electric strength test:			
	Test voltage 900 V (see 8.7.2)			
	a)			Р
	b)			N
	c)			Р
	d)			N
	e) 2000 V			N
	Test current 2,8 I _N	1,4 A		
	Tripping within > 0,1 s up to	(s) (s)	(s)	
	- 60 s	0,1s < t < 60 s		P
_	- 120 s			N

TEST REPORT

IEC 60 898

Circuit-Breakers for overcurrent protection for household and similar installation

Report reference No	500097-01/01/4
Tested by (printed name and signature):	Jan Hlavatý
Approved by (printed name and signature)	Jan Hlavatý
Date of issue:	14.02.2005
This report is based on a blank test report t TRF originator (see below).	hat was prepared by SGS Fimko Ltd using information obtained from the
Testing Laboratory Name	Elektrotechnický zkušební ústav
Address	Pod Lisem 129
Testing location	171 02 Praha 71-Troja, Czech Republic
Applicant's Name	BONEGA Velkoobchod s.r.o.
Address	696 66 Sudoměřice nad Moravou 302, Czech Republic
·:	
Test specification	
Standard:	IEC 60898 (2 nd ed):1995
Test procedure:	CB
Procedure deviation:	N/A
Non-standard test method:	N/A
Test Report Form	
Test Report Form No	60898A/00-12
TRF originator	ÖVE
Master TRF	dated 00-07
Copyright reserved to the bodies participate participating in the C.I.G (CCA-ENEC).	ing in the IECEE Schemes (CB and CB-FCS) and/or the bodies
Test item description	Circuit breakers for overcurrent protection for household and similar installation
Trademark:	BONEGA
Series	PEP-10J
Model and/or type reference:	PEP-10J D 2 (Ip)
Rating(s):	AC 230/400 V, 2 A, 50 Hz

for overcurrent protection for household and similar installations
single-pole
unenclosed
panel board
not associated with the mechanical mounting
D
30
10 000
terminal with stirrup (indirect pressure)
230/400 V
2 A
50 Hz
N(.A.)
P(ass)
F(ail)
27.01.2005
07.02. to 14.02.2005

General remarks

This report shall not be reproduced except in full without the written approval of the testing laboratory.

The test results presented in this report relate only to the item(s) tested.

"(see remark #)" refers to a remark appended to the report.

"(see Annex #)" refers to an annex appended to the report.

Throughout this report a comma is used as the decimal separator.

Copy of marking plate and summary of test results:	
See Annex No:1/1-4 of Test Report No:500097-01/01/1.	
Photograph See Annex No: 2/1 of Test Report No:500097-01/01/1.	

	IEC 60898			-0		
	TESTS "D" 3 samples		UNANCO PERSONAL PROPERTY AND ADMINISTRATION AND ADM			
7.6	Automatic operation					
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.				P	
8.10	Tests: DO	DO 1	DO 2	DO 3		
	I _N (A)		2			
	Sect. (mm²)		1			
	Instantaneous tripping current		D			
8.10.1	Test of time-current characteristic					
8.10.1.1	Test current 1,13 I _N (A) starting from cold for: 2,26 A					
	- 1 h (I _N ≤ 63 A)				P	
	- 2 h (I _N > 63 A)		***		N	
	No tripping				Р	
	Then steadily increased within 5 s to 1,45 I _N (A)		2,9 A		~~	
	- Tripping within	[min]	[min]	[min]		
	- 1h (≤ 63 A)	52"			Р	
	- 2h (> 63 A)				N	
8.10.1.2	Test current 2,55 I _N (A) starting from cold for: 5,1 A					
	opening time not less than 1 s or more than	[s]	[s]	[s]		
	- 60 s	24"			Р	
	- 120 s				Ν	
8.10,2	Test of instantaneous tripping:					
8.10.2.1	□ B - Type				N	
	Test current 3I _N (A), starting from cold			_		
	Opening time:	[s]	[s]	[s]		
	- 0,1s ≤ t ≤ 45s (≤ 32A)				N	
	- 0,1s ≤ t ≤ 90s (> 32A)				N	
	Test current 5 I _N (A), starting from cold				N	
	Tripping less than 0,1 s				N	
8.10.2.2	□ C - Type				Ν	
_	Test current 5I _N (A), starting from cold					
_	Opening time:	[s]	[s]	[s]		
	- 0,1s ≤ t ≤ 15s (≤ 32A)				N	
	- 0,1s ≤ t ≤ 30s (> 32A)				N	
	Test current 10 I _N (A), starting from cold				N	
	Tripping less than 0,1 s				N	
8.10.2.3	□ D - Type				Р	
	Test current 10I _N (A), starting from cold		20 A			
	Opening time:	[s]	[s]	[s]		

	IEC 60898		
	- 0,1s ≤ t ≤ 4s (≤ 32A)	7"	Р
	- 0,1s ≤ t ≤ 8s (> 32A)		N
	Test current 20 I _N (A), starting from cold	40 A	
	Tripping less than 0,1 s	0,005"	P
8.10.3	Test of effect of single pole loading on the tripping characteristic of multipole circuit-breakers:		N
	Test current 1,1 It (A), (two pole) starting from cold		
	Tripping within	[min] [min] [min]	
	- 1h		N
	- 2h		N
	Test current 1,2 It (A), (three pole or four pole) starting from cold		
	Tripping within	[min] [min] [min]	
	- 1h		N
	- 2h		N
8.10.4	Test of effect of ambient temperature on the tripping characteristics		
	a) Ambient temperature of (-5 ± 2)°C		P
	Test current 1,13 I _N (A)	2,26 A	
	- Passed for 1h		Р
	- Passed for 2h		N
_	Current is then steadily increased to 1,9 I _N (A) within 5s	3,8 A	
	Tripping within	[min] [min] [min]	
	- 1h	49"	P
	- 2h		N
	b) Ambient temperature of (40 ± 2)°C		Р
	Test current I _N (A)	2 A	Р
	No tripping within		
	- 1h		P
	- 2h	_	N

TEST REPORT

IEC 60 898

Circuit-Breakers for overcurrent protection for household and similar installation

Report reference No	500097-01/01/5	
Tested by (printed name and signature):	Jaroslav Klípa	The !.
Approved by (printed name and signature)	•	The fe
Date of issue:	14.02.2005	7
This report is based on a blank test report t TRF originator (see below).	hat was prepared by SGS Fimko Ltd using information ob	otained from the
Testing Laboratory Name	Elektrotechnický zkušební ústav	
Address	Pod Lisem 129	
Testing location	171 02 Praha 71-Troja, Czech Republic	
Applicant's Name	BONEGA Velkoobchod s.r.o.	
Address	696 66 Sudoměřice nad Moravou 302, Czech Republic	
:		
Test specification		
Standard	IEC 60898 (2 nd ed):1995	
Test procedure	CB	
Procedure deviation	N/A	
Non-standard test method:	N/A	
Test Report Form		
Test Report Form No	60898A/00-12	
TRF originator	ÖVE	
Master TRF	dated 00-07	
Copyright reserved to the bodies participat participating in the C.I.G (CCA-ENEC).	ing in the IECEE Schemes (CB and CB-FCS) and/or the b	podies
Test item description	Circuit breakers for overcurrent protection for household installation	d and similar
Trademark:	BONEGA	
Series	PEP-10J	
Model and/or type reference	PEP-10J D 3 (1p)	
Rating(s)	AC 230/400 V, 3 A, 50 Hz	

Test items particulars:	
Type of circuit-breaker:	for overcurrent protection for household and similar installations
Number of poles	single-pole
Protection against external influences:	unenclosed
Method of mounting	panel board
Method of connection	not associated with the mechanical mounting
Instantaneous tripping current:	D
Ambient air temperature (°C)	30
Energy limiting class:	
Rated short-circuit capacity (A)	10 000
Type of terminal	terminal with stirrup (indirect pressure)
Value of rated operational voltage:	230/400 V
Value of rated current:	3 A
Value of rated frequency	50 Hz
Test case verdicts	
Test case does not apply to the test object:	N(.A.)
Test item does meet the requirement:	P(ass)
Test item does not meet the requirement	F(ail)
Testing	
Date of receipt of test item	27.01.2005
Date(s) of performance of test	07.02. to 14.02.2005

General remarks

This report shall not be reproduced except in full without the written approval of the testing laboratory.

The test results presented in this report relate only to the item(s) tested.

"(see remark #)" refers to a remark appended to the report.

"(see Annex #)" refers to an annex appended to the report.

Throughout this report a comma is used as the decimal separator.

Copy of marking plate and summary of test results: See Annex No:1/1-4 of Test Report No:500097-01/01/1. Photograph See Annex No.2/1 of Test Report No:500097-01/01/1.

	Opening time:	[s]	[s]	[s]	•-
	Test current 10I _N (A), starting from cold		30 A		-
8.10.2.3	□ D - Type				P
	Tripping less than 0,1 s		1370		N
	Test current 10 I _N (A), starting from cold	_		9	N
	- 0,1s ≤ t ≤ 30s (> 32A)				N
	- 0,1s ≤ t ≤ 15s (≤ 32A)	_			N
	Opening time:	[s]	[s]	[s]	
_	Test current 5I _N (A), starting from cold		_	_	
3.10.2.2	□ C - Type				N
	Tripping less than 0,1 s				Ν
	Test current 5 I _N (A), starting from cold			_	Ν
	- 0,1s ≤ t ≤ 90s (> 32A)				N
	- 0,1s ≤ t ≤ 45s (≤ 32A)				N
	Opening time:	[s]	[s]	[s]	
	Test current 3I _N (A), starting from cold				
8.10.2.1	□ B - Type				N
8.10.2	Test of instantaneous tripping:				
	- 120 s				N
	- 60 s	24"			P
	opening time not less than 1 s or more than	[s]	[s]	[s]	
8.10.1.2	Test current 2,55 I _N (A) starting from cold for:		7,65 A		
	- 2h (> 63 A)				N
	- 1h (≤ 63 A)	19"			Р
	- Tripping within	[min]	[min]	[min]	
	Then steadily increased within 5 s to 1,45 I _N (A)		4,35 A		
	No tripping				P
	- 2 h (I _N > 63 A)				N
	- 1 h (I _N ≤ 63 A)				Р
8.10.1.1	Test current 1,13 I _N (A) starting from cold for:		3,39 A		
8.10.1	Test of time-current characteristic				
	Instantaneous tripping current		D		
	Sect. (mm²)		1		**
	I _N (A)		3		
8.10	Tests: DO	DO 1	DO 2	DO 3	
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.				Р
7.6	Automatic operation				
	TESTS "D" 3 samples				

	IEC 60898		
	- 0,1s ≤ t ≤ 4s (≤ 32A)	5"	P
	- 0,1s ≤ t ≤ 8s (> 32A)		N
_	Test current 20 I _N (A), starting from cold	60 A	
	Tripping less than 0,1 s	0,006"	Р
8.10.3	Test of effect of single pole loading on the tripping characteristic of multipole circuit-breakers:		N
	Test current 1,1 It (A), (two pole) starting from cold		
	Tripping within	[min] [min] [min]	
	- 1h		N
_	- 2h	_	И
	Test current 1,2 It (A), (three pole or four pole) starting from cold	<u> </u>	
	Tripping within	[min] [min] [min]	
	- 1h		N
	- 2h		N
8.10.4	Test of effect of ambient temperature on the tripping characteristics		
	a) Ambient temperature of (-5 ± 2)°C		Р
	Test current 1,13 I _N (A)	3,39 A	
	- Passed for 1h		P
	- Passed for 2h		N
	Current is then steadily increased to 1,9 I_N (A) within 5s	5,7 A	
	Tripping within	[min] [min] [min]	
	- 1h	51"	P
	- 2h		N
	b) Ambient temperature of (40 ± 2)°C		Р
	Test current I _N (A)	3 A	Р
	No tripping within		
	- 1h		P
	- 2h		N

TEST REPORT

IEC 60 898

Circuit-Breakers for overcurrent protection for household and similar installation

Report reference No	500097-01/01/6	Jaroslav Klípa 🛴 1
rested by (printed name and signature):		Jaroslav Kilpa
Approved by (printed name and signature)		Jan Hlavatý
Date of issue	14.02.2005	
This report is based on a blank test report t TRF originator (see below).	hat was prepared by SGS Fimko Ltd	using information obtained from the
Testing Laboratory Name	Elektrotechnický zkušební ústav	
Address	Pod Lisem 129	
Testing location	171 02 Praha 71-Troja, Czech Repo	ablic
Applicant's Name	BONEGA Velkoobchod s.r.o.	
Address	696 66 Sudoměřice nad Moravou 3	02, Czech Republic
Test specification		
Standard	IEC 60898 (2 nd ed):1995	
Test procedure	СВ	
Procedure deviation	N/A	
Non-standard test method	N/A	
Test Report Form		
Test Report Form No	60898A/00-12	
TRF originator	ÖVE	
Master TRF	dated 00-07	
Copyright reserved to the bodies participat participating in the C.I.G (CCA-ENEC).	ing in the IECEE Schemes (CB and C	CB-FCS) and/or the bodies
Test item description	Circuit breakers for overcurrent pro installation	tection for household and similar
Trademark	BONEGA	
Series	PEP-10J	
Model and/or type reference	PEP-10J D 4 (1p)	
Rating(s)	AC 230/400 V, 4 A, 50 Hz	

Test items particulars:	
Type of circuit-breaker:	for overcurrent protection for household and similar installations
Number of poles:	single-pole
Protection against external influences:	unenclosed
Method of mounting:	panel board
Method of connection:	not associated with the mechanical mounting
Instantaneous tripping current:	D
Ambient air temperature (°C):	30
Energy limiting class:	
Rated short-circuit capacity (A)	10 000
Type of terminal:	terminal with stirrup (indirect pressure)
Value of rated operational voltage:	230/400 V
Value of rated current:	4 A
Value of rated frequency:	50 Hz
Test case verdicts	
Test case does not apply to the test object:	N(.A.)
Test item does meet the requirement:	P(ass)
Test item does not meet the requirement:	F(ail)
Testing	
Date of receipt of test item:	27.01.2005
Date(s) of performance of test	07.02. to 14.02.2005

General remarks

This report shall not be reproduced except in full without the written approval of the testing laboratory.

The test results presented in this report relate only to the item(s) tested.

"(see remark #)" refers to a remark appended to the report.

"(see Annex #)" refers to an annex appended to the report.

Throughout this report a comma is used as the decimal separator.

Copy of marking plate and summary of test results:
See Annex No:1/1-4 of Test Report No:500097-01/01/1.
Photograph See Annex No:2/1 of Test Report No:500097-01/01/1.

TRF No. 60898_A TRF originator: ÖVE

	IEC 60898					
	TESTS "D" 3 samples					
7.6	Automatic operation					
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.				Р	
8.10	Tests: DO	DO 1	DO 2	DO 3		
	I _N (A)		4			
	Sect. (mm²)		1			
	Instantaneous tripping current		D			
8.10.1	Test of time-current characteristic					
8.10.1.1	Test current 1,13 I _N (A) starting from cold for:		4,52 A		*-	
	- 1 h (I _N ≤ 63 A)				P	
	- 2 h (I _N > 63 A)				N	
	No tripping				P	
	Then steadily increased within 5 s to 1,45 I _N (A)		5,8 A			
	- Tripping within	[min]	[min]	[min]		
	- 1h (≤ 63 A)	17"			P	
	- 2h (> 63 A)				N	
8.10.1.2	Test current 2,55 I _N (A) starting from cold for:		10,2 A			
	opening time not less than 1 s or more than	[s]	[s]	[s]		
	- 60 s	24"			P	
	- 120 s				N	
8.10.2	Test of instantaneous tripping:					
8.10.2.I	□ B - Type				N	
	Test current 3I _N (A), starting from cold					
	Opening time:	[s]	[s]	[s]		
	- 0,1s ≤ t ≤ 45s (≤ 32A)				N	
	- 0,1s ≤ t ≤ 90s (> 32A)				Ν	
	Test current 5 I _N (A), starting from cold		1		N	
	Tripping less than 0,1 s				N	
8.10.2.2	☐ C - Type				N	
	Test current 51 _N (A), starting from cold			2 3 1 1 1		
	Opening time:	[s]	[s]	[s]		
	- 0,1s ≤ t ≤ 15s (≤ 32A)				N	
	-0,1s ≤ t ≤ 30s (> 32A)		BLIEFE		N	
	Test current 10 I _N (A), starting from cold		Man Ellip		N	
	Tripping less than 0,1 s				N	
8.10.2.3	□ D-Type				P	
	Test current $10I_N(\Lambda)$, starting from cold		40 A		~	
	Opening time:	[s]	[s]	[s]		

	IEC 60898		
	- 0,1s ≤ t ≤ 4s (≤ 32A)	5"	Р
	- 0,1s ≤ t ≤ 8s (> 32A)	~~~	N
	Test current 20 I _N (A), starting from cold	80 A	
	Tripping less than 0,1 s	0,006"	- P
8.10.3	Test of effect of single pole loading on the tripping characteristic of multipole circuit-breakers:		N
	Test current 1,1 It (A), (two pole) starting from cold		
	Tripping within	[min] [min] [min	
	- 1h		N
	- 2h		N
	Test current 1,2 It (A), (three pole or four pole) starting from cold		
	Tripping within	[min] [min] [min]	
	- 1h		N
	- 2h		N
8.10.4	Test of effect of ambient temperature on the tripping characteristics	_	
	a) Ambient temperature of (-5 ± 2)°C		Р
	Test current 1,13 I _N (A)	4,52 A	~~
	- Passed for 1h		Р
	- Passed for 2h		N
	Current is then steadily increased to 1,9 I _N (A) within 5s	7,6 A	
	Tripping within	[min] [min] [min]]
_	- 1h	45"	Р
	- 2h	,	N
	b) Ambient temperature of (40 ± 2)°C		Р
_	Test current I _N (A)	4 A	Р
	No tripping within		
	- 1h		Р
_	- 2h		N

TEST REPORT

IEC 60 898

Circuit-Breakers for overcurrent protection for household and similar installation

Report reference No	500097-01/01/7
Tested by (printed name and signature):	Jaroslav Klípa Sklu ha
Approved by (printed name and signature)	Jaroslav Klípa July
Date of issue	14.02.2005
This report is based on a blank test report t TRF originator (see below).	hat was prepared by SGS Fimko Ltd using information obtained from the
Testing Laboratory Name	Elektrotechnický zkušební ústav
Address	Pod Lisem 129
Testing location	171 02 Praha 71-Troja, Czech Republic
Applicant's Name	BONEGA Velkoobchod s.r.o.
Address	696 66 Sudoměřice nad Moravou 302, Czech Republic
:	
Test specification	
Standard	IEC 60898 (2 nd ed):1995
Test procedure	CB
Procedure deviation	N/A
Non-standard test method	N/A
Test Report Form	
Test Report Form No	60898A/00-12
TRF originator	ÖVE
Master TRF	dated 00-07
Copyright reserved to the bodies participat participating in the C.I.G (CCA-ENEC).	ing in the IECEE Schemes (CB and CB-FCS) and/or the bodies
Test item description:	Circuit breakers for overcurrent protection for household and similar installation
Trademark:	BONEGA
Series	PEP-10J
Model and/or type reference	PEP-10J D 6 (1p)
Rating(s)	AC 230/400 V, 6 A, 50 Hz

Test items particulars:	
Type of circuit-breaker	for overcurrent protection for household and similar installations
Number of poles	single-pole
Protection against external influences:	unenclosed
Method of mounting:	panel board
Method of connection:	not associated with the mechanical mounting
Instantaneous tripping current:	D
Ambient air temperature (°C):	30
Energy limiting class:	
Rated short-circuit capacity (A):	10 000
Type of terminal:	terminal with surrup (indirect pressure)
Value of rated operational voltage:	230/400 V
Value of rated current:	6 A
Value of rated frequency	50 Hz
Test case verdicts	
Test case does not apply to the test object:	N(.A.)
Test item does meet the requirement:	P(ass)
Test item does not meet the requirement:	F(ail)
Testing	
Date of receipt of test item	27.01.2005
Date(s) of performance of test:	07.02. to 14.02.2005

General remarks

This report shall not be reproduced except in full without the written approval of the testing laboratory.

The test results presented in this report relate only to the item(s) tested.

"(see remark #)" refers to a remark appended to the report.

"(see Annex #)" refers to an annex appended to the report.

Throughout this report a comma is used as the decimal separator.

Lopy of marking plate and summary of test results:	
See Annex No:1/1-4 of Test Report No:500097-01/01/1.	
Photograph See Annex No:2/1 of Test Report No:500097-01/01/1.	
	=

	IEC 60898			4.000	
	TESTS "D" 3 samples				
7.6	Automatic operation	_			
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.				Р
8.10	Tests: DO	DO 1	DO 2	DO 3	
	$I_{N}(A)$		6		
	Sect. (mm²)		1		
	Instantaneous tripping current		D		
8.10.1	Test of time-current characteristic			- Andrew Control	
8.10.1.1	Test current 1,13 I _N (A) starting from cold for:		6,78 A		
	- 1 h (I _N ≤ 63 A)	TE			Р
	- 2 h (I _N > 63 A)		 -		N
	No tripping				Р
	Then steadily increased within 5 s to 1,45 I _N (A)		8,7 A		
	- Tripping within	[min]	[min]	[min]	
	- 1h (≤ 63 A)	8" -			P
	- 2h (> 63 A)				N
8.10.1.2	Test current 2,55 I _N (A) starting from cold for:		15,3 A		
	opening time not less than 1 s or more than	[s]	[s]	[s]	
	- 60 s	10"			P
	- 120 s				N
8.10.2	Test of instantaneous tripping:				
8.10.2.1	□ B - Type				N
	Test current 3I _N (A), starting from cold			_	
	Opening time:	[s]	[s]	[s]	
	- 0,1s ≤ t ≤ 45s (≤ 32A)				N
	- 0,1s ≤ t ≤ 90s (> 32A)				N
	Test current 5 l _N (A), starting from cold				N
	Tripping less than 0,1 s				N
8.10.2.2	□ C - Type				N
	Test current 5I _N (A), starting from cold				
	Opening time:	[s]	[s]	[s]	
	- 0,1s ≤ t ≤ 15s (≤ 32A)				N
	- 0,1s ≤ t ≤ 30s (> 32A)				N
	Test current 10 I _N (A), starting from cold				N
	Tripping less than 0,1 s				N
8.10.2.3	□ D - Type				P
	Test current 10l _N (A), starting from cold		60 A		
	Opening time:	[s]	[s]	[s]	

	IEC 60898		
	- 0,1s ≤ t ≤ 4s (≤ 32A)	3"	Р
	- 0,1s ≤ t ≤ 8s (> 32A)		N
	Test current 20 I _N (A), starting from cold	120 A	
	Tripping less than 0,1 s	0,008"	P
8.10.3	Test of effect of single pole loading on the tripping characteristic of multipole circuit-breakers:		N
	Test current 1,1 It (A), (two pole) starting from cold		
	Tripping within	[min] [min] [min]	
	- 1h		N
	- 2h		N
	Test current 1,2 It (A), (three pole or four pole) starting from cold		
	Tripping within	[min] [min] [min]	
	- 1h		N
	- 2h		N
8.10.4	Test of effect of ambient temperature on the tripping characteristics		
	a) Ambient temperature of (-5 ± 2)°C		Р
	Test current 1,13 I _N (A)	6,78 A	
	- Passed for 1h		Р
	- Passed for 2h		N
	Current is then steadily increased to 1,9 I_N (A) within 5s	11,4 A	
	Tripping within	[min] [min] [min]	
	- 1h	22"	Р
	- 2h		N
	b) Ambient temperature of (40 ± 2)°C		Р
	Test current I _N (A)	6 A	P
	No tripping within		
	- 1h		Р
	- 2h		N

TEST REPORT

IEC 60 898

Circuit-Breakers for overcurrent protection for household and similar installation

Report reference No	500097-01/01/8
Tested by (printed name and signature):	Jaroslav Klipa
Approved by (printed name and signature)	Jan Hlavatý
Date of issue:	14.02.2005
This report is based on a blank test report t TRF originator (see below).	that was prepared by SGS Fimko Ltd using information obtained from the
Testing Laboratory Name	Elektrotechnický zkušební ústav
Address	Pod Lisem 129
Testing location	171 02 Praha 71-Troja, Czech Republic
Applicant's Name	BONEGA Velkoobchod s.r.o.
Address	696 66 Sudoměřice nad Moravou 302, Czech Republic
Test specification	
Standard	IEC 60898 (2 nd ed):1995
Test procedure	CB
Procedure deviation	N/A
Non-standard test method	N/A
Test Report Form	
Test Report Form No	60898A/00-12
TRF originator	ÖVE
Master TRF	dated 00-07
Copyright reserved to the bodies participat participating in the C.I.G (CCA-ENEC).	ing in the IECEE Schemes (CB and CB-FCS) and/or the bodies
Test item description	Circuit breakers for overcurrent protection for household and similar installation
Trademark:	BONEGA
Series	PEP-10J
Model and/or type reference	PEP-10J D 10 (1p)
Rating(s)	AC 230/400 V, 10 A, 50 Hz

Test items particulars:	
Type of circuit-breaker:	for overcurrent protection for household and similar installations
Number of poles	single-pole
Protection against external influences	unenclosed
Method of mounting	panel board
Method of connection:	not associated with the mechanical mounting
Instantaneous tripping current:	D
Ambient air temperature (°C)	30
Energy limiting class	
Rated short-circuit capacity (A):	10 000
Type of terminal:	terminal with stirrup (indirect pressure)
Value of rated operational voltage:	230/400 V
Value of rated current:	10 A
Value of rated frequency:	50 Hz
Test case verdicts	
Test case does not apply to the test object:	N(.A.)
Test item does meet the requirement:	P(ass)
Test item does not meet the requirement:	F(ail)
Testing	
Date of receipt of test item:	27.01.2005
Date(s) of performance of test	07.02. to 14.02.2005

General remarks

This report shall not be reproduced except in full without the written approval of the testing laboratory.

The test results presented in this report relate only to the item(s) tested.

Throughout this report a comma is used as the decimal separator.

[&]quot;(see remark #)" refers to a remark appended to the report.

[&]quot;(see Annex #)" refers to an annex appended to the report.

Copy of marking plate and summary of test results:
See Annex No:1/1-4 of Test Report No:500097-01/01/1.
Photograph See Annex No:2/1 of Test Report No:500097-01/01/1.

IEC 60898

	TESTS "D" 3 samples				22.5
7.6	Automatic operation				
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		_		Р
8.10	Tests: DO	DO 1	DO 2	DO 3	
	$I_{N}(A)$		10		
	Sect. (mm²)		1,5		
	Instantaneous tripping current		D		
8.10.1	Test of time-current characteristic				
8.10.1.1	Test current 1,13 $I_N(A)$ starting from cold for:		11,3 A		
_	- 1 h (I _N ≤ 63 A)				Р
	- 2 h (I _N > 63 A)			_	N
	No tripping				Р
	Then steadily increased within 5 s to 1,45 I _N (A)		14,5 A		
	- Tripping within	[min]	[min]	[min]	
_	- 1h (≤ 63 A)	9" -			Р
	- 2h (> 63 A)				N
8.10.1.2	Test current 2,55 I _N (A) starting from cold for:		25,5 A		
	opening time not less than 1 s or more than	[s]	[s]	[s]	
	- 60 s	10"			P
	- 120 s				N
8.10.2	Test of instantaneous tripping:				
8.10.2.1	□ B - Type				N
	Test current 3I _N (A), starting from cold				
	Opening time:	[s]	[s]	[s]	
	- 0,1s ≤ t ≤ 45s (≤ 32A)	_			N
	- 0,1s ≤ t ≤ 90s (> 32A)				N
	Test current 5 I _N (A), starting from cold	_			N
	Tripping less than 0,1 s				N
8.10.2.2	□ C - Type				N
	Test current 5I _N (A), starting from cold			1080.4	
	Opening time:	[s]	[s]	[s]	
	- 0,1s ≤ t ≤ 15s (≤ 32A)				N
	- 0,1s ≤ t ≤ 30s (> 32A)		_		N
	Test current 10 I _N (A), starting from cold				N
	Tripping less than 0,1 s				N
8.10.2.3	□ D - Type				Р
	Test current 10I _N (A), starting from cold	_	100 A		
	Opening time:	[s]	[s]	[s]	

Page 5 of 5

	IEC 60898			
	- 0,1s ≤ t ≤ 4s (≤ 32A)	4"		Р
	- 0,1s ≤ t ≤ 8s (> 32A)		_	N
	Test current 20 I _N (A), starting from cold	200	А	N-24
	Tripping less than 0,1 s	0,007"		P
8.10.3	Test of effect of single pole loading on the tripping characteristic of multipole circuit-breakers:			N
	Test current 1,1 It (A), (two pole) starting from cold			
	Tripping within	[min] [mir	n] [min]	
	- 1h			N
	- 2h			N
	Test current 1,2 It (A), (three pole or four pole) starting from cold			
	Tripping within	[min] [mir	n] [min]	
	- 1h		dlama	N
	- 2h			Ν
8.10.4	Test of effect of ambient temperature on the tripping characteristics			
	a) Ambient temperature of (-5 ± 2)°C		_	P
	Test current 1,13 I _N (A)	11,3 A	4	
	- Passed for 1h			Р
	- Passed for 2h			N
	Current is then steadily increased to 1,9 I_N (A) within 5s	19 A		
	Tripping within	[min] [mir	n] [min]	
	- 1h	20"		P
	- 2h			N
	b) Ambient temperature of (40 ± 2)°C			P
	Test current I _N (A)	10	А	Р
	No tripping within			
	- 1h			Р
	- 2h			N

EZŪ Praha nabizi:

- zkoušení výrobků z hlediska elektrické a mechanické bezpečnosti, EMC, hluku, vibrací apod., včetně vypracování kompletních zkušebních protokolů,
- certifikaci výrobků jako podklad pro posouzení shody,
- **značku ESČ a certifikát EZÚ označující shodu vlastností výrobku s požadavky technických norem** pro elektrickou bezpečnost,
- mezinárodně uznávané certifikáty CCA, CB a EMEDCA,
- celoevropské značky ENEC a KEYMARK označující shodu vlastností výrobku s požadavky technických norem pro elektrickou bezpečnost,
- značku CCA-EMC označující shodu vlastností výrobku s požadavky technických norem pro EMC,
- certifikaci dle norem ČSN EN ISO 9000 a 14 001, ČSN EN 46 000 a BS 8800,
- certifikáty pro systémy řízení: EZÚ, CQS a IQNet,
- posouzení dokumentace výrobku,
- přípravu prohlášení o shodě podle zákona 22/97 Sb. i pro značení CE,
- metrologické služby,
- skolení, konzultace.

EZÚ Prague offers:

- testing of products from the point of view of their electrical and mechanical safety, EMC, noise, vibration, etc., including the preparation of complete test reports,
- certification of products as basic material for the preparation of the Conformity Declaration,
- ESČ Mark and the EZÚ Certificate indicating the conformity of the properties of the given product with the requirements of the standards for electrical safety.
- internationally acknowledged CCA, CB and EMEDCA Certificates,
- Pan-European marks ENEC and KEYMARK indicating the conformity of the properties of a product with the requirements of the standards for electrical safety,
- the CCA-EMC Mark indicating conformity of the properties of the product with the requirements of the standards concerning EMC,
- certification in compliance with the standards EN ISO 9000 and EN ISO 14 001, EN 46 000 and BS 8800,
- EZÚ, CQS and IQNet Certificates for Systems of Management,
- assessment of the documentation of a product,
- elaboration of the Conformity Declaration,
- metrological services,
- training, consultations.

